

		Optional			
5.	Part-E	Above 10 kW to 100 kW	-	-	-
6.	Part-F	Above 100 kW to 500 kW	-	-	-

Note:

1. Electrical Circle wise applications of RTS plant capacity received from different consumers through rodalee portal is enclosed as **Annexure – Z** for reference of the bidder.
2. The CFA would be admissible as per MNRE scheme guidelines
3. For common facilities in Group Housing Societies/Residential Welfare Associations (GHS/RWA) etc. the allowed RTS capacity shall be limited up to 500 kWp (@ 10 kWp per house), with the upper limit being inclusive of individual rooftop plants already installed by individual residents in that GHS/RWA at the time of installation. Bidders are requested to quote Minimum Capacities in each part as per above table.
4. It is mandatory for the bidder to quote all the categories except part –E & F above in the same tendering process otherwise all of the proposals in which the Bidder has participated to be disqualified. The RTS capacity in part –E & part-F shall be allotted to the successful bidder as under:
 - i. In case of RTS plant capacity (above 10 kW to 100 kW & above 100 kW to 500 kW) is identified by the successful bidder, then the same will be allotted to the same successful bidder
 - OR**
 - ii. In case of application for RTS plant capacity (above 10 kW to 100 kW & above 100 kW to 500 kW) is received from www.rodalee.com, then the allotment shall be issued based on the performance of bidder during execution of the project. The time of installation of sanctioned capacity shall also be considered during the performance analysis of the bidder.
5. APDCL reserves the right for diversion of capacity from one bidder/ category to another for 100% utilization of capacity sanctioned by MNRE, Gol

Sai Santanu Bora

Chief General Manager (NRE),

Assam Power Distribution Company Limited
Bijulee Bhawan (Annex Building), Paltanbazar
Guwahati – 01