

- (5) In third Proviso to Sub-regulation (2) of Regulation 7 of the Principal Regulations, the words "49.70 Hz and above" shall be substituted by the words "49.85 Hz and above".

5. Amendment of Regulation 8 of the Principal Regulations:

- (1) In Sub-regulation (1) of Regulation 8 of the Principal Regulations, the words "49.70 Hz and above" shall be substituted by the words "49.85 Hz and above".
- (2) In Sub-regulation (2) of Regulation 8 of the Principal Regulations, the words "50.10 Hz and above" shall be substituted by the words "50.05 Hz and above".
- (3) In Sub-regulation (4) of Regulation 8 of the Principal Regulations, the words "below 49.70 Hz in accordance with the methodology specified in sub-Regulation (6) of this regulation and the same shall be equivalent to 100% of the Charge for Deviation of 824.04 Paise / kWh corresponding to the grid frequency of 'below 49.70 Hz' " shall be substituted by the words "below 49.85 Hz in accordance with the methodology specified in sub-Regulation (6) of this regulation and the same shall be equivalent to 100% of the Charge for Deviation of 800 Paise / kWh corresponding to the grid frequency of 'below 49.85 Hz' ".
- (4) In Sub-regulation (5) of Regulation 8 of the Principal Regulations, the words "49.70 Hz and above" shall be substituted by the words "49.85 Hz and above".
- (5) In Sub-regulation (6) of Regulation 8 of the Principal Regulations, the words "below 49.70 Hz" shall be substituted by the words "below 49.85 Hz".
- (6) In proviso to Sub-regulation (6) of Regulation 8 of the Principal Regulations, the words "below 49.70 Hz" shall be substituted by the words "below 49.85 Hz".
- (7) Sub-regulation (7) of Regulation 8 of the Principal Regulations shall be substituted by the following:
- "In the event of sustained deviation from schedule in one direction (positive or negative) by any state entity (buyer or seller), such entity shall correct its position in the manner as specified below:
- If the sustained deviation from schedule continues in one direction (positive or negative) for 6 time blocks, the state entity (buyer or seller), shall correct its position, by making the sign of its deviation from schedule changed or by remaining in the range of +/- 2% with reference to its scheduled position at least once, latest by 7th time block.

Provided that violation of the requirement under this Sub-regulation shall attract an additional charge as specified in the table below:

No. of Violation in Day	Additional Charge Payable
From first to fifth violation	For each violation, an additional charge @ 3% of daily base DSM charge payable or receivable
From sixth to tenth violation	For each violation, an additional charge @ 5% of daily base DSM charge payable or receivable
From eleventh violation onwards	For each violation, an additional charge @ 10% of daily base DSM charge payable or receivable

Provided further that counting of number of sign change violations under this Sub-regulation shall start afresh at 00.00 Hrs for each day.

Provided also that payment of additional charge for failure to adhere to sign change requirement as specified under this Sub-regulation shall not be applicable to:

- renewable energy generators which are State entities.
- run of river projects without pondage.
- any infirm injection of power by a generating station prior to CoD of a unit during testing and commissioning activities.
- any drawal of power by a generating station for the start-up activities of a unit.

Illustration:

A state entity having a sustained deviation from time blocks t1 to t7, shall correct its position either by changing the sign of its deviation (from positive to negative or negative to positive as the case may be) or come back in the range of $\pm 2\%$ with reference to its schedule latest by the end of time block t7. In case, such sign change does not take place or it fails to come back in the aforesaid range by the end of time block t7, but such correction of position takes place from time block t8 up to time block t12, then an additional charge shall be levied equivalent to one violation. Further, in case, the sign change does not take place or it fails to come back in the range as aforesaid latest by the end of t13, but the correction in position takes place from time block t14 upto time block t18, then the additional charge shall be levied for two violations and so on."