

INDEX

NAME OF WORK: - "Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri.."

Serial No.	Contents	Page No
1.	Index <u>PART - A</u>	1
2.	Press Tender Notice	2
3.	Information and Instructions for contractor for e-tendering	3 to 5
4.	Notice inviting tenders (CPWD - 6)	6 to 10
5.	Tender and contract	11 to 12
6.	Schedule "A" to "F"	13 to 16
7.	Integrity pact	17 to 22
8.	Form of Earnest Money (Bank Guarantee)	23
9.	Form of Performance Guarantee (Bank Guarantee)	24
10.	Technical specification and Additional Special conditions	25 to 44 And 48 to 55
11.	List of acceptance and make	45 to 47
12.	Drawing.	Nil
13.	Modification of Clause 12 of GCC 2020.	
14.	Modification of CPWD Works Manual 2019.	
15.	Modification of in GCC 2020 and CPWD-6.	
16.	Modification in CPWD-6 (Modified)	
17.	Modification in schedule F of GCC 2020.	
18.	Schedule of Quantity	56 to 57

Certified that this NIT document contains pages 01 to 58.

This N.I.T.is approved for **Rs 57,14,000/-**(Rupees fifty seven Lac fourteen thousand only)

Vide No. : 06/Engg/NBF/Elect/2022-23

EE(Elect)
FTR HQ BSF NB

BORDER SECURITY FORCE
NOTICE INVITING e-TENDER
NIT No- 06/Engg/NBF/Elect/2022-23

The Executive Engineer (Electrical), Ftr HQ NB on behalf of President of India invites online tender from approved and eligible contractors of CPWD and those of appropriate list of MES, BSNL, Railways, state PWD having valid electrical license or manufacturer / Authorized OEM/ MSME in relevant field of Solar Power Plant equipments for the work "Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri"

The enlistment of the contractors should be valid on the last date of submission of bids.
In case of last date of submission of bid is extended, the enlistment of contractors should be valid on the original date of submission of bids.

~~The contractors should also have following experience.~~

- ~~a) Have constructed synthetic Volleyball court for School, Colleges and Clubs in last three year where inter state level tournament can take place.~~
- ~~b) Have constructed synthetic Volleyball court of National and International quality as classified by ITF.~~

~~The contractors responding to this tender notice should also provide following documents:-~~

- ~~a) Financial details of last one year.~~
- ~~b) ITF Certificate pace rating to be 3,4 and 5 (as classified by ITF). All 3 certificates to be provided.~~
- ~~c) Completion certificate from the authorities for whome volleyball court has been constructed to be attached for authenticity.~~

Details of work are as under:-

Name of Work: Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri...

Estimated Cost	:-	Rs.57,14,000/-
Earnest money	:-	Rs.1,14,280 /-
Period of completion	:-	180 days
Last time and date of submission of bid online	:-	10.11.2022 (1800 HRS)
Date of submission of documents	:-	11.11.2022 (1000 HRS)
Date of opening bids	:-	14.11.2022 (1100 HRS)

The tender forms and other details can be seen and downloaded from the website www.eprocure.gov.in and www.bsf.nic.in

**INFORMATION AND INSTRUCTIONS FOR CONTRACTORS FOR E-TENDERING FORMING PART OF NIT
AND TO BE POSTED ON WEBSITE**

The Executive Engineer (Electrical), Ftr HQ NB on behalf of President of India invites online tender from approved and eligible contractors of CPWD and those of appropriate list of MES, BSNL, Railways, state PWD having valid electrical license or manufacturer / Authorized OEM / MSME in relevant field of Solar Power Plant equipments for the following work :-

Page 3

Name of work & Location	Estimated cost put to tender	Earnest Money	Period of Completion	Last date & time of submission of bid through Website	Period during which EMD, Tender Fees and other Documents physically shall be submitted in tender box in Acctt branch the office of DIG SHQ BSF Jalpaiguri	Time & date of opening of bid
"Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri"	Rs. 57,14,000/-	Rs 1,14,280/-	180 days	10.11.2022 AT 1800 HRS	11.11.2022 up to 1000 Hrs	14.11.2022 AT 1100 HRS

- The intending bidder must read the terms and conditions of CPWD-6 carefully. He should only submit his bid if he considers himself eligible and he is in possession of all the documents required.
- Information and Instructions for bidders posted on website shall form part of bid document.
- The bid document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents can be seen and downloaded from website www.eprocure.gov.in and <http://www.bsf.nic.in> free of cost.
- The bid can only be submitted after uploading the mandatory documents such as Demand Draft or Pay order or Banker's Cheque or Deposit at call Receipt or Fixed Deposit Receipts and Bank Guarantee of any Scheduled Bank towards cost of EMD in favour of **DIG SHQ BSF Jalpaiguri** and other documents as specified.
- Those contractors not registered on the website mentioned above, are required to get registered beforehand. If needed they can be imparted training on online bidding process as per details available on the website.
- The intending bidder must have valid class-III digital signature to submit the bid.
- On opening date, the contractor can login and see the bid opening process. After opening of bids he will receive the competitor bid sheets.
- Contractor can upload documents in the form of JPG format and PDF format.
- Contractor must survey the site of work before quoting the rates of each item.
Therefore, if any cell is left blank and no rate is quoted by the bidder, rate of such item shall be treated as "0" (ZERO).
- ~~Before commencement of work contractor should produce sample of turf along with certificate issued by approved Govt. agency/Lab certifying that this sample of turf is as per specification.~~
- The tender document consisting of plans, specifications, the schedule of quantities of various types of Items to be executed and the set of terms and conditions of the contract to be complied by the contractor with and other necessary documents are uploaded on website [eprocure.gov.in](http://www.eprocure.gov.in).

12. General contract condition 2020 for Maintenance/Construction work will be applicable as per “relevant tender work”.

(ER. Rakesh Khanna)
Dy Commandant/EE(Elect)
FTR HQ BSF NB (WB)

No. Engg/Tender/FTR (NB)/2022/

Dated, the June 2022

Distribution: -

- | | |
|--|----------------------------------|
| 1. IT Cell FTR HQ NB | : - for publicity in BSF website |
| 2. SHQ BSF KNJ/SLG/JPG/RGj | : - -do- |
| 3. EE (Elect) CPWD Office, Matigara, Siliguri | : - -do- |
| 4. Contractor Association, Bidahan Road Siliguri | : - -do- |
| 5. EE(Elect), Railway New Jalpaiguri Division | : - -do- |
| 6. Vigilance cell FTR HQ NB | : - For info please. |
| 7. Acctt Branch FTR HQ NB | : - For info please. |
| 8. Notice Board | |
| 9. File. | |

List of Documents to be scanned and uploaded through online

List of Documents to be scanned/uploaded within the period of bid submission.

CPWD Registered Firms :-

1. Scanned copy of Earnest Money in prescribed form in favour of the “**DIG SHQ BSF Jalpaiguri**”
2. Scanned copy of valid CPWD Registration Certificate of appropriate electrical category or valid registration of MES, Railways, BSNL and State PWD of appropriate electrical category.
3. Scanned copy of GST Registration
4. Valid Electrical license.
5. PAN Card, GST& IT return latest as applicable.

Non CPWD Registered Contractor

1. Scanned copy of Earnest Money in prescribed form in favour of the “**DIG SHQ BSF Jalpaiguri**”
2. Scanned copy of valid CPWD Registration Certificate of appropriate electrical category or valid registration of MES, Railways, BSNL and State PWD of appropriate electrical category.
3. Scanned copy of GST Registration
4. Valid Electrical license.
5. Certificates of similar type of work experience as per para 1.2.1/1.2.2/1.2.3 of Form-6.
6. PAN Card, GST& IT return latest as applicable.

Manufacturer/ Authored OEM /MSME

1. Manufacturer/Authorized OEM certificate
2. MNRE approval certificate
3. PAN Card, GST& IT return latest as applicable.
4. MSE registration certificate of relevant category (If required exemption of EMD)
5. Certificates of similar type of work experience as per para 1.2.1/1.2.2/1.2.3 of Form-6.

Common for All bidder's

- (i) FORM "D" FORMAT FOR UNDERSTANDING THE PROJECT SITE
(on Bidder Letter Head) as per format provided in NIT
- (ii) FORM "E" **FORMAT FOR NO DEVIATION CERTIFICATE** (on Bidder Letter Head) as per format provided in NIT
- (iii) FORM "F" **FORMAT FOR INTEGRITY PACT** (on Bidder Letter Head) as per format provided in NIT
- (iv) Signed copy of NIT
- (v) Affidavit as per clause 1.2.3 of Form 6.

"I/We undertake and confirm that eligible similar work(s) has/have not been got executed through another contractor on back to back basis. Further, if such a violation comes to the notice of Department, then I/We shall be debarred for tendering in BSF/CPWD in future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-charge shall be free to forfeit the entire amount of the Earnest money /Performance Guarantee."

(vi) ~~Scanned copy of EPF Registration certificate.~~

(vii) ~~Scanned copy of Undertaking regarding EPF provision as per following Performa.~~

~~"I..... Son of Resident of hereby give an undertaking that I/we have registered as per the EPF and miscellaneous provision Act. 1952 and our registration no. is We undertake to keep it valid during the currency of contract. In case at any stage, it is found that the information given by me is false /incorrect BSF shall have the absolute right to take any action as deemed fit/without any prior intimation to me".~~

~~(Signature of Contractor)~~

~~(Seal of the firm)~~

18) The following undertaking in this regard shall also be uploaded by the intending bidders:-

Scanned copy of Undertaking –A TO ABIDE BY CPWD form 6 & 8

" I.....Son ofResident ofhereby give an undertaking that I have read and I am aware of a the Clause and sub-clause of CPWD Form 6 & 8 and other terms and conditions as per NIT and I confirm that abide by all the terms and conditions available in original standard"

Note: EMD should be deposited on due date and time in sealed envelope in the office of "DIG SHQ BSF Jalpaiguri" in Account branch.

List of Documents to be Submitted through Tender Box in the Office of DIG SHQ BSF Jalpaiguri (Account branch) in Two Envelope system (i.e EMD and Tender Fees in one Envelope and Others documents are in another envelope) with name of Work. (Except MSME registered)

1. Original of Earnest Money.

Earnest Money Deposit:-

Firms registered with Micro and Small Enterprise (MSEs) in relevant field i.e service/supply category for installation of solar power plant are exempted for depositing the EMD.
However these firms should submit work experience as per Para 1.2.1.

Govt. of India
BORDER SECURITY FORCE
Notice Inviting e-Tender
CPWD-6 FOR e-Tendering

The Executive Engineer (Electrical), Ftr HQ NB on behalf of President of India invites online tender from approved and eligible contractors of CPWD and those of appropriate list of MES, BSNL, Railways, state PWD having valid electrical license or manufacturer / Authorized OEM / MSME of relevant category of Solar Power Plant equipments for the following work :-

The enlistment of the contractors should be valid on the last date of submission of bids.

In case the last date of submission of bid is extended, the enlistment of contractor should be valid on the original date of submission of bids.

1.1 The work is estimated to cost **Rs 57,14,000/-** This estimate, however, is given merely as a rough guide.

1.1.1 The authority competent to approve NIT for the combined cost and belonging to the major discipline will consolidate NITs for calling the bids. He will also nominate Division which will deal with all matters relating to the invitation of bids.

For composite bid, besides indicating the combined estimated cost put to bid, should clearly indicate the estimated cost of each component separately. The eligibility of bidders will correspond to the combined estimated cost of different components put to bid.

1.2 ~~Intending bidders is eligible to submit the bid provided he has definite proof from the appropriate authority, which shall be to the satisfaction of the competent authority, of having satisfactorily completed similar works of magnitude specified below:-~~

~~Criteria of eligibility for submission of bid documents~~

1.2.1 Conditions for Non-CPWD as well as non CPWD registered contractors, : **Supplying , Installation, Testing and Commissioning of solar power plant)**

(i) **Three similar works each of value not less than 40%**

or

(ii) **two similar work each of value not less than 60%**

or

(iii) **One similar work of value not less than 80% of estimated cost (all figures rounded to nearest Convenient figure in last 7 years ending last day of the month previous to the one in which tender are invited.)**

1.2.2 Nil

To become eligible for issue of bid, the bidders shall have to furnish an affidavit as under:-

I/We undertake and confirm that eligible similar works(s) has/have not been got executed through another contractor on back to back basis. Further that, if such a violation comes to the notice of Department, then I/we shall be debarred for bidding in BSF in future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-Charge shall be free to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee. (Scanned copy to be uploaded at the time of submission of bid)

1.2.3 ~~When bids are invited from non CPWD contractors and CPWD class II contractors as per provisions of clause 1.2.1 above, it will be mandatory for non CPWD contractors and CPWD class II contractors to upload the work experience certificate(s) and the affidavit as per the provisions of clause 1.2.2. But for such bids, Class I contractors of CPWD are eligible to submit the bids without submission of work experience certificate and affidavit. Therefore, CPWD class I contractors shall upload two separate letters for experience certificate and affidavit that these documents are not required to be submitted by them. Uploading of these two letters is mandatory otherwise system will not clear mandatory fields.~~

2. Agreement shall be drawn with the successful bidders on prescribed Form No. CPWD 7/8 (or other Standard Form as mentioned) which is available as a Govt. of India Publication and also available on website www.eprocure.gov.in. Bidders shall quote his rates as per various terms and conditions of the said form which will form part of the agreement.
3. The time allowed for carrying out the work will be **180 days** as defined in schedule 'F' or from the first date of handing over of the site, whichever is later, in accordance with the phasing, if any, indicated in the bid documents.
4. The site for the work is available.
OR
~~The site for the work shall be made available in parts as specified below:-~~
.....
5. The bid document consisting of plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents except Standard General Conditions of Contract Form can be seen on website www.eprocure.gov.in free of cost.
6. After submission of the bid the contractor can re-submit revised bid any number of times but before last time and date of submission of bid as notified.
7. While submitting the revised bid, contractor can revise the rate of one or more item(s) any number of times (he need not re-enter rate of all the items) but before last time and date of submission of bid as notified.
8. When bids are invited in three stage system and if it is desired to submit revised financial bid then it shall be mandatory to submit revised financial bid. If not submitted then the bid submitted earlier shall become invalid.
9. Earnest Money can be paid in the form of ~~Treasury Challan~~ or Demand Draft or Pay order or Banker's Cheque or Deposit at Call Receipt or Fixed Deposit Receipt (drawn in favour of **DIG SHQ BSF Jalpaiguri** ~~along with Bank Guarantee~~ of any Scheduled Bank wherever applicable. A part of earnest money is acceptable in the form of bank guarantee also. In such case, 50% of earnest money or Rs. 20 lac, whichever is less, will have to be deposited in shape prescribed above, and balance in shape of Bank Guarantee of any scheduled bank. The intending bidder has to fill all the details such as Banker's name, Demand Draft/Fixed Deposit Receipt /Pay Order/ Banker's Cheque/Bank Guarantee number, amount and date.
The amount of EMD can be paid by multiple Demand Draft / Pay Order /Banker's Cheque / Deposit at call receipt / Fixed Deposit Receipts along with multiple Bank Guarantee of any Scheduled Bank if EMD is also acceptable in the form of Bank Guarantee. Firms having MSME in relevant field are exempted from EMD.
- (i) **Cost of Bid NIL.**
- (ii) ~~Treasury Challan~~ or Demand Draft or Pay Order or Banker's Cheque or Deposit at Call Receipt or FDR or Bank Guarantee against EMD, Cost of Bid Document shall be placed in single sealed envelope superscripted as "Earnest Money" with name of work and due date of opening of the bid also mentioned thereon.
Copy of Enlistment Order ~~and certificate of work experience~~ and other documents as specified in the press notice shall be scanned and uploaded to the e-Tendering website within the period of bid submission and certified copy of each shall be deposited in a separate envelop marked as "Other Documents".
Both the envelopes shall be placed in another envelope with due mention of Name of work, date & time of opening of bids and to be submitted in the office of DIG SHQ BSF Jalpaiguri, Actt branch after last date & time of submission of online bid and up to 1800 Hrs on 10.11.2022 The documents submitted shall be at 1000 Hrs on 11.11.22022.
Online bid documents submitted by intending bidders shall be opened only of those bidders, whose Earnest Money Deposit / MSME and other documents placed in the envelope are found in order.
The bid submitted shall be opened at 1100 Hrs on 14.11.2022.
10. The bid submitted shall become invalid and cost of bid & e-Tender processing fee shall not be refunded if:
- (i) The bidder is found ineligible.
- (ii) The bidders do not upload all the documents (including GST registration) as stipulated in the bid document.

- (iii) **If the bidder except MSME registered doesn't deposit EMD before opening of financial bid and within prescribed due date and time.**
- (iv) **If any discrepancy is noticed between the documents as uploaded at the time of submission of bid and hard copies as submitted physically by the lowest tenderer in the office of tender opening authority.**

- Page 8
11. The contractor whose bid is accepted will be required to furnish performance guarantee of 3% (Three Percent) of the bidding amount within the period specified in Schedule F. This guarantee shall be in the form of cash (~~in case guarantee amount is less than Rs. 10000/-~~) or Deposit at Call receipt of any scheduled bank/Banker's cheque of any scheduled bank/Demand Draft of any scheduled bank/Pay order of any Scheduled Bank of any scheduled bank (in case guarantee amount is less than Rs. 1,00,000/-) or Government Securities or Fixed Deposit Receipts or Guarantee Bonds of any Scheduled Bank or the State Bank of India in accordance with the prescribed form. In case the contractor fails to deposit the said performance guarantee within the period as indicated in Schedule 'F', including the extended period if any, the Earnest Money deposited by the contractor shall be forfeited automatically without any notice to the contractor.
 12. Intending Bidders are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their bids as to the nature of the ground and sub-soil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their bid. Bidders shall be deemed to have full knowledge of the site Whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The bidders shall be responsible for arranging and maintaining at His own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a bid by a bidders implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the Government and local conditions and other factors having a bearing on the execution of the work.
 13. The competent authority on behalf of the President of India does not bind itself to accept the lowest or any other bid and reserves to itself the authority to reject any or all the bids received without the assignment of any reason. All bids in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the bidders shall be summarily rejected.
 14. Canvassing whether directly or indirectly, in connection with bidders is strictly prohibited and the bids submitted by the contractors who resort to canvassing will be liable for rejection.
 15. The competent authority on behalf of President of India reserves to himself the right of accepting the whole or any part of the bid and the bidders shall be bound to perform the same at the rate quoted.
 16. The contractor shall not be permitted to bid for works in the ~~BSF & CPWD Circle (Division in case of contractors of Horticulture/Nursery category)~~ responsible for award and execution of contracts, in which his near relative is posted a Senior Accountant or as an officer in any capacity between the grades of Superintending Engineer and Junior Engineer (both inclusive). He shall also intimate the names of persons who are working with him in any capacity or are subsequently employed by him and who are near relatives to any gazetted officer in the ~~Central Public Works Department/BSF or in the Ministry of Urban Development/MHA~~. Any breach of this condition by the contractor would render him liable to be removed from the approved list of contractors of this Department.
 17. No Engineer of Gazetted Rank or other Gazetted Officer employed in Engineering or Administrative duties in an Engineering Department of the Government of India is allowed to work as a contractor for a period of one year after his retirement from Government service, without the prior permission of the Government of India in writing. This contract is liable to be cancelled if either the contractor or any of his employees is found any time to be

such a person who had not obtained the permission of the Government of India as aforesaid before submission of the bid or engagement in the contractor's service.

18. The bid for the works shall remain open for acceptance for a period of ninety (90) days from the date of opening of bids. If any bidders withdraws his bid before the said period or issue of letter of acceptance, whichever is earlier, or makes any modifications in the terms and conditions of the bid which are not acceptable to the department, then the Government shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money as aforesaid. Further the bidders shall not be allowed to participate in the rebidding process of the work.

19. This notice inviting Bid shall form a part of the contract document. The successful bidders/contractor, on acceptance of his bid by the Accepting Authority shall within 15 days from the stipulated date of start of the work, sign the contract consisting of:-

- a) The Notice Inviting Bid, all the documents including additional conditions, specifications and drawings, if any, forming part of the bid as uploaded at the time of invitation of bid and the rates quoted online at the time of submission of bid and acceptance thereof together with any correspondence leading thereto.
- b) Standard C.P.W.D. Form 7/8 or other Standard C.P.W.D. Form as applicable.

20. **For Composite Bids**

20.1.1 ~~The Executive Engineer in charge of the major component will call bids for the composite work. The cost of bid document and Earnest Money will be fixed with respect to the combined estimated cost put to tender for the composite bid.~~

20.1.2 ~~The bid document will include following three components:~~

Part A:- ~~CPWD-6, CPWD-7/8 including schedule A to F for the major component of the work, Standard **General Conditions of Contract for CPWD 2010 as amended/modified up to CON 260 DT 15-03-2012.**~~

Part B:- ~~General / specific conditions, specifications and schedule of quantities applicable to major component of the work.~~

Part C:- ~~Schedule A to F for minor component of the work. (SE/EE in charge of major component shall also be competent authority under clause 2 and clause 5 as mentioned in schedule A to F for major components), General/specific conditions, specifications and schedule of quantities applicable to minor component(s) of the work.~~

20.1.3 ~~The bidders must associate himself, with agencies of the appropriate class eligible to bid for each of the minor component individually.~~

20.1.4 ~~The eligible bidders shall quote rates for all items of major component as well as for all items of minor components of work.~~

20.1.5 ~~After acceptance of the bid by competent authority, the EE in charge of major component of the work shall issue letter of award on behalf of the President of India. After the work is awarded, the main contractor will have to enter into one agreement with EE in charge of major component and has also to sign two or more copies of agreement depending upon number of EE's/DDH in charge of minor components. One such signed set of agreement shall be handed over to EE/DDH in charge of minor component(s). EE of major component will operate part A and part B of the agreement. EE/DDH in charge of minor component(s) shall operate Part C along with Part A of the agreement.~~

20.1.6 ~~Entire work under the scope of composite bid including major and all minor components shall be executed under one agreement.~~

- 20.1.7 ~~Security Deposit will be worked out separately for each component corresponding to the estimated cost of the respective component of works. The Earnest Money will become part of the security deposit of the major components of work.~~
- 20.1.8 ~~The main contractor has to associate agency(s) for minor component(s) conforming to eligibility criteria as defined in the bid document and has to submit detail of such agency(s) to Engineering charge of minor component(s) within prescribed time. Name of the agency(s) to be associated shall be approved by Engineer incharge of minor component(s).~~
- 20.1.9 ~~In case the main contractor intends to change any of the above agency/agencies during the operation of the contract, he shall obtain prior approval of Engineer in charge of minor component. The new agency/agencies shall also have to satisfy the laid down eligibility criteria. In case Engineer in-charge is not satisfied with the performance of any agency, he can direct the contractor to change the agency executing such items of work and this shall be binding on the contractor.~~
- 20.1.10 ~~The main contractor has to enter into agreement with contractor(s) associated by him for execution of minor component(s). Copy of such agreement shall be submitted to EE/DDH in charge of each minor component as well as to EE in charge of major component. In case of change of associate contractor, the main contractor has to enter into agreement with the new contractor associated by him.~~
- 20.1.11 ~~Running payment for the major component shall be made by EE of major discipline to the main contractor. Running payment for minor components shall be made by the Engineer in charge of the discipline of minor component directly to the main contractor.~~
- 20.1.12 ~~Final bill of whole work shall be finalized and paid by the EE of major component. Engineer(s) in charge of minor component(s) will prepare and pass the final bill for their component of work and pass on the same to the EE of major component for including in the final bill for composite contract.~~

Note: All strikeout lines treated as deleted.

**CPWD- 8
GOVERNMENT OF INDIA
BORDER SECURITY FORCE**

Item Rate Tender & Contract for Works

(A) Tender for the work of:- “Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri..

- (i) To be submitted by 1800 Hrs on “10.11.2022 to **DIG SHQ BSF Jalpaiguri.**
- (ii) To be opened in presence of tenderers who may be present at 1100 hours on 14.11.2022 in the office of **DIG SHQ BSF Jalpaiguri.**

Issued to

Signature of officer issuing the documents

Designation.

Date of Issue

TENDER

I/We have read and examined the notice inviting tender, schedule, A, B, C, D, E & F Specifications applicable, Drawings & Designs, General Rules and Directions, Conditions of Contract, clauses of contract, Special conditions, Schedule of Rate & other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.

I/We hereby tender for the execution of the work specified for the President of India within the time specified in Schedule 'F' viz., schedule of quantities and in accordance in all respect with the specifications, designs, drawing and instructions in writing referred to in Rule-1 of General Rules and Directions and in Clause 11 of the Conditions of contract and with such materials as are provided for, by, and in respect of accordance with, such conditions so far as applicable.

We agree to keep the tender open for 90 days from the due date of its opening / ninety days from the date of opening of financial bid in case tenders are invited on 2/3 envelop system (strike out as the case may be) and not to make any modification in its terms and conditions.

A sum of Rs.1,14,280/-is hereby forwarded receipt treasury challan/deposit at call receipt of a scheduled bank/fixed deposit receipt of scheduled bank/demand draft of a scheduled bank/bank guarantee issued by a scheduled bank as earnest money. If I/We, fail to furnish the prescribed performance guarantee within prescribed period. I/We agree that the said President of India or his

Successors, in office shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely. Further, if I/We fail to commence work as specified, I/We agree that President of India or the successors in office shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said earnest money and the performance guarantee absolutely, otherwise the said earnest money shall be retained by him towards security deposit to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to those in excess of that limit at the rates to be determined in accordance with the provision contained in Clause 12.2 and 12.3 of the tender form. Further, I/We agree that in case of forfeiture of Earnest Money & Performance Guarantee as aforesaid. I/We shall be debarred for participation in the re-tendering process of the work.

I/We undertake and confirm that eligible similar work(s) has/have not been got executed through another contractor on back to back basis. Further that, if such a violation comes to the notice of Department, then I/We shall be debarred for tendering in BSF in future forever. Also, if such a violation comes to the notice of Department before date of start of work, the Engineer-in-Charge shall be free to forfeit the entire amount of Earnest Money Deposit/Performance Guarantee.

I/We hereby declare that I/We shall treat the tender documents drawings and other records connected with the work as secret/confidential documents and shall not communicate information/derived therefrom to any person other than a person to whom I/We am/are authorized to communicate the same or use the information in any manner prejudicial to the safety of the State.

Dated:

Signature of Contractor

Witness:

Postal Address

Address:

Occupation:

ACCEPTANCE

The above tender (as modified by you as provided in the letters mentioned hereunder) is accepted by me for an on behalf of the President of India for a sum of Rs.....

(Rupees.....).
.....).

The letters referred to below shall form part of this contract agreement:-

- (a)
- (b)
- (c)

For & on behalf of President of India

Signature

Designation

Dated:

PROFORMA OF SCHEDULES CPWD

(Separate Performa for Civil, Elect. & Hort. Works in case of Composite Tenders)

SCHEDULE 'A'

Schedule of quantities (as per PWD-3)

Page No 51 For Elect Works.

SCHEDULE 'D'

Extra schedule for specific requirements/document for the work, if any.

NIL

SCHEDULE 'E'

Reference to General Conditions of contract.-

General conditions of contract for CPWD works-2020 with amendments issued up to the last date of receipt of tender.

Name of Work: - "Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri..

- (i) Estimated cost of work : **Rs. 57,14,000/-**
- (ii) Earnest Money : **Rs. 1,14,280/-**
- (iii) Performance Guarantee : 3% of tendered value
- (iv) Security Deposit : 2.5% of tendered value

SCHEDULE 'F'

GENERAL RULES & DIRECTIONS

Officer Inviting Tender :

**Dy Comdt/EE(Elect)
FTR HQ BSF NB**

Maximum percentage for quantity of Items of work to be executed beyond which rates are to be determined in accordance with Clauses 12.2 & 12.3.

See below.

Definitions:

- 2(v) Engineer-in-Charge : **Dy Comdt/EE (Elect) FTR HQ BSF NB**
- 2(viii) Accepting Authority : **Dy Comdt/EE (Elect) FTR HQ BSF NB**
- 2(x) Percentage on cost of materials and labour to cover all overheads and profits. : **15%**

2(xi) Standard Schedule of Rates : DSR-2018 with Correction slips issued up to the last date prescribed for submission of tender and market rate.

2(xii) Department : BSF

9(ii) Standard CPWD contract Form GCC 2020 : Yes.

CPWD form 7/8 as modified and corrected upto date

Clause 1

i) Time allowed for submission of : 07 days

Performance guarantee from the date of Issue of letter of acceptance in days.

ii) Maximum allowable extension : 15 Days.

With late fee @ 0.1% per day of Performance Guarantee amount beyond the period provided in (i) above (1 to 15 days)

Clause 2

Authority for fixing compensation under clause2. : SE(Elect)/Comdt (Elect), FHQ, BSF CGO Complex, New Delhi.

Clause 2A

Whether clause 2 A shall be applicable : Yes

Clause 5

Number of days from the date of issue of letter of acceptance for reckoning date of start : 15 days

Mile stone(s) as per table given below:

TABLE OF MILE STONE (S)

S.No.	Description of milestone (Physical)	Time Allowed in days (from date of start)	Amount to be with-held in case of non achievement of milestone
NIL			

Time allowed for execution of work. : 180 Days

Authority to decide:

(i) Extension of time : Dy Comdt/EE(Elect) FTR HQ BSF NB

(ii) Rescheduling of Milestones : Dy Comdt/EE(Elect) FTR HQ BSF NB

(iii) Shifting of date of start in case of delay in handing over of site : Dy Comdt/EE(Elect) FTR HQ BSF NB

PROFORMA OF SCHEDULES Clause 5 Schedule of handing over of site

Part	Portion of site	Description	Time Period for handing over reckoned from date of issue of letter of intent.
Part A	Portion without any hindrance		
Part B	Portions with encumbrances		
Part C	Portions dependent on work of other agencies		

Clause 5 A

Applicable Clause 5/clause 5A) : Applicable

Clause 7

Gross work to be done together with net payment/adjustment of advances for material collected, if any, since the last such payment for being eligible to interim payment. : **25% of Contract value**

Clause 7A

Whether clause 7A shall be applicable : **Applicable**

Clause 10 A

List of testing equipment to be provided by the contractor at site lab : **Applicable**

Clause 10B(ii)

Whether clause 10 B (ii) shall be applicable? : **No**

Clause 10 C

Component of labour expressed as percent of value of work : **Not Applicable**

Clause 10CC : **Not applicable**

Clause 11

Specifications to be followed for execution of work : **Electrical CPWD specifications Internal & External, solar power and energy efficiency in Govt buildings, labour act and rules with revisions and correction slips issued up to dated**

Clause 12

Authority to decide deviation upto 1.5 of Tender Amount : **EE/SE(elect)**

12.2 & 12.3

Deviation limit beyond which clauses 12.2 & 12.3 shall apply for building work. : **30%**

12.5 (i) Deviation Limit beyond which clauses 12.2. & 12.3 shall apply for foundation work (except earthwork). : **50%**

(ii) Deviation Limit for items in earthwork subhead of DSR or related items : **100%**

Clause 16

Competent Authority for deciding reduced rates

: **SE(Elect)/Comdt (Elect), FHQ, BSF**

Clause-18:- List of mandatory machinery, tools

Plants to be deployed by the contractor of Engg in charge. **As per requirement at site and as per direction**

Clause 19C Authority to deciding penalty for each default – SE(Elect)/Comdt (E) FHQ BSF/EE(E)

Clause 19D Authority to deciding penalty for each default – SE(Elect)/Comdt (E) FHQ BSF/EE(E)

Clause 19G Authority to deciding penalty for each default – SE(Elect)/Comdt (E) FHQ BSF/EE(E)

Clause 19K Authority to deciding penalty for each default – SE(Elect)/Comdt (E) FHQ BSF/EE(E)

Clause 25

Constitution of Dispute Redressal Committee (DRC) for total claims more than Rs. 25 Lacs:

1. Chairman – IG of concerned Ftr.
2. Member –DIG of some other Ftr.
3. Member- Any nominated officer by concerned Ftr IG
4. Member- Concerned EE (Only to present the case).

Constitution of Dispute Redressal Committee (DRC) for total claims upto Rs. 25 Lacs:

1. Chairman – DIG of some other Sector to be nominated by concerned IG.
2. Member- DC of some other sector to be nominated by IG.
3. Member- Senior Accountant/AO of Ftr. to be nominated by IG
4. Concerned Assistant Engineer (Only to present the case).

******Ftr. IG is competent to appoint DRC in both cases.**

Clause 32

“Requirement of Technical representative and recovery rate”

“Requirement of Technical Representative(s) and Recovery Rate”							
S.No.	Minimum Qualification of Technical Representative	Discipline	Designation (Principal Technical/ Technical representative)	Minimum experience	Number	Rate at which recovery shall be made from the contractor in the event of not fulfilling provision of Clause 36(i)	
						Figure	Words
1.	Graduate Engineer or Diploma Engineer	Elect	Principal Technical Representative (Project Planning/site /billing Engineer)	2 years or 5 years	1	15,000/- Per Month	Fifteen Thousand per month
<p>“Assistant Engineers retired from Government services that are holding Diploma will be treated at par with Graduate Engineers.”</p> <p>Diploma holder with minimum 10 year relevant experience with a reputed construction co. can be treated at par with Graduate Engineers for the purpose of such deployment subject to the condition that such diploma holders should not exceed 50% of requirement of degree engineers.</p>							

Clause 38

: Not applicable.

INTEGRITY PACT

To,
.....
.....
.....

Page 17

Sub: NIT No. 06/Engg/NBF/Elect/2022-23

For the work :- “Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri..

Dear Sir,

It is here by declared that BSF is committed to follow the principle of transparency, equity and competitiveness in public procurement.

The subject Notice Inviting Tender (NIT) is an invitation to offer made on the condition that the Bidder will sign the integrity Agreement, which is an integral part of tender/bid documents, failing which the tenderer/bidder will stand disqualified from the tendering process and the bid of the bidder would be summarily rejected.

This declaration shall form part and parcel of the Integrity Agreement and signing of the same shall be deemed as acceptance and signing of the Integrity Agreement on behalf of the BSF

Yours faithfully

DC(E)/EE(E)

INTEGRITY PACT

To,
DC(E)/EE(E),
FTR HQ BSF NB

Page 18

Submission of Tender for the “Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri.

Dear Sir,

I/We acknowledge that BSF is committed to follow the principles thereof as enumerated in the Integrity Agreement enclosed with the tender/bid document.

I/We agree that the Notice Inviting Tender (NIT) is an invitation to offer made on the condition that I/We will sign the enclosed integrity Agreement, which is an integral part of tender documents, failing which I/We will stand disqualified from the tendering process. I/We acknowledge that THE MAKING OF THE BID SHALL BE REGARDED AS AN UNCONDITIONAL AND ABSOLUTE ACCEPTANCE of this condition of the NIT.

I/We confirm acceptance and compliance with the Integrity Agreement in letter and spirit and further agree that execution of the said Integrity Agreement shall be separate and distinct from the main contract, which will come into existence when tender/bid is finally accepted by BSF. I/We acknowledge and accept the duration of the Integrity Agreement, which shall be in the line with Article 1 of the enclosed Integrity Agreement.

I/We acknowledge that in the event of my/our failure to sign and accept the Integrity Agreement, while submitting the tender/bid, BSF shall have unqualified, absolute and unfettered right to disqualify the tenderer/bidder and reject the tender/bid in accordance with terms and conditions of the tender/bid.

Yours faithfully

(Duly authorized signatory of the Bidder)

**To be signed by the bidder and same signatory competent / authorized to
sign the relevant contract on behalf of BSF.**

INTEGRITY AGREEMENT

This Integrity Agreement is made at on this day of20.....

BETWEEN

President of India represented through Executive Engineer

(Hereinafter referred as the '**Principal/Owner**', which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)

AND

.....
(Name and Address of the Individual/firm/Company)

through (Hereinafter referred to as the (Details of duly authorized signatory)
"Bidder/Contractor" and which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)

Preamble

WHEREAS the Principal / Owner has floated the Tender (NIT No.....) (hereinafter referred to as "**Tender/Bid**") and intends to award, under laid down organizational procedure, contract for "....."
(**herein after referred to as the "Contract"**).

AND WHEREAS the Principal/Owner values full compliance with all relevant laws of the land, rules, regulations, economic use of resources and of fairness/transparency in its relation with its Bidder(s) and Contractor(s).

AND WHEREAS to meet the purpose aforesaid both the parties have agreed to enter into this Integrity Agreement (hereinafter referred to as "**Integrity Pact**" or "**Pact**"), the terms and conditions of which shall also be read as integral part and parcel of the Tender/Bid documents and Contract between the parties.

NOW, THEREFORE, in consideration of mutual covenants contained in this Pact, the parties hereby agree as follows and this Pact witnesses as under:

Article 1: Commitment of the Principal/Owner

- 1) The Principal/Owner commits itself to take all measures necessary to prevent corruption and to observe the following principles:
 - (a) No employee of the Principal/Owner, personally or through any of his/her family members, will in connection with the Tender, or the execution of the Contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - (b) The Principal/Owner will, during the Tender process, treat all Bidder(s) with equity and reason. The Principal/Owner will, in particular, before and during the Tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the Tender process or the Contract execution.
 - (c) The Principal/Owner shall endeavor to exclude from the Tender process any person, whose conduct in the past has been of biased nature.

- 2) If the Principal/Owner obtains information on the conduct of any of its employees which is a criminal offence under the Indian Penal code (IPC)/Prevention of Corruption Act, 1988 (PC Act) or is in violation of the principles herein mentioned or if there be a substantive suspicion in this regard, the Principal/Owner will inform the Chief Vigilance Officer and in addition can also initiate disciplinary actions as per its internal laid down policies and procedures.

Article 2: Commitment of the Bidder(s)/Contractor(s)

- 1) It is required that each Bidder/Contractor (including their respective officers, employees and agents) adhere to the highest ethical standards, and report to the Government / Department all suspected acts of **fraud or corruption or Coercion or Collusion** of which it has knowledge or becomes aware, during the tendering process and throughout the negotiation or award of a contract.
- 2) The Bidder(s)/Contractor(s) commits himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the Tender process and during the Contract execution:
 - a) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm, offer, promise or give to any of the Principal/Owner's employees involved in the Tender process or execution of the Contract or to any third person any material or other benefit which he/she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the Tender process or during the execution of the Contract.
 - b) The Bidder(s)/Contractor(s) will not enter with other Bidder(s) into any undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to cartelize in the bidding process.
 - c) The Bidder(s)/Contractor(s) will not commit any offence under the relevant IPC/PC Act. Further the Bidder(s)/Contractor(s) will not use improperly, (for the purpose of competition or personal gain), or pass on to others, any information or documents provided by the Principal/Owner as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
 - d) The Bidder(s)/Contractor(s) of foreign origin shall disclose the names and addresses of agents/representatives in India, if any. Similarly Bidder(s)/Contractor(s) of Indian Nationality shall disclose names and addresses of foreign agents/representatives, if any. Either the Indian agent on behalf of the foreign principal or the foreign principal directly could bid in a tender but not both. Further, in cases where an agent participate in a tender on behalf of one manufacturer, he shall not be allowed to quote on behalf of another manufacturer along with the first manufacturer in a subsequent/parallel tender for the same item.
- e) The Bidder(s)/Contractor(s) will, when presenting his bid, disclose any and all payments he has made, is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the Contract.
- 3) The Bidder(s)/Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.
- 4) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm indulge in fraudulent practice **means a willful misrepresentation or omission of facts or submission of fake/forged documents in order to induce public official to act in reliance thereof, with the purpose of obtaining unjust advantage by or causing damage to justified interest of others and/or to influence the procurement process to the detriment of the Government interests.**
- 5) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm use Coercive Practices (means the act of obtaining something, compelling an action or influencing a decision through intimidation, threat or the use of force directly or indirectly, where potential or actual injury may befall upon a person, his/ her reputation or property to influence their participation in the tendering process).

Article 3: Consequences of Breach

Without prejudice to any rights that may be available to the Principal/Owner under law or the Contract or its established policies and laid down procedures, the Principal/Owner shall have the following rights in case of breach of this Integrity Pact by the Bidder(s)/Contractor(s) and the Bidder/ Contractor accepts and undertakes to respect and uphold the Principal/Owner's absolute right:

- 1) If the Bidder(s)/Contractor(s), either before award or during execution of Contract has committed a transgression through a violation of Article 2 above or in any other form, such as to put his reliability or credibility in question, the Principal/Owner after giving 14 days notice to the contractor shall have powers to disqualify the Bidder(s)/Contractor(s) from the Tender process or terminate/determine the Contract, if already executed or exclude the Bidder/Contractor from future contract award processes. The imposition and duration of the

exclusion will be determined by the severity of transgression and determined by the Principal/Owner. **Such exclusion may be forever or for a limited period as decided by the Principal/Owner.**

2) **Forfeiture of EMD/Performance Guarantee/Security Deposit:**

If the Principal/Owner has disqualified the Bidder(s) from the Tender process prior to the award of the Contract or terminated/determined the Contract or has accrued the right to terminate/determine the Contract according to Article 3(1), the Principal/Owner apart from exercising any legal rights that may have accrued to the Principal/Owner, may in its considered opinion forfeit the entire amount of Earnest Money Deposit, Performance Guarantee and Security Deposit of the Bidder/Contractor.

3) **Criminal Liability:**

If the Principal/Owner obtains knowledge of conduct of a Bidder or Contractor, or of an employee or a representative or an associate of a Bidder or Contractor which constitutes corruption within the meaning of IPC Act, or if the Principal/Owner has substantive suspicion in this regard, the Principal/Owner will inform the same to law enforcing agencies for further investigation.

Article 4: Previous Transgression

- 1) The Bidder declares that no previous transgressions occurred in the last 5 years with any other Company in any country confirming to the anticorruption approach or with Central Government or State Government or any other Central/State Public Sector Enterprises in India that could justify his exclusion from the Tender process.
- 2) If the Bidder makes incorrect statement on this subject, he can be disqualified from the Tender process or action can be taken for banning of business dealings/ holiday listing of the Bidder/Contractor as deemed fit by the Principal/ Owner.
- 3) If the Bidder/Contractor can prove that he has resorted / recouped the damage caused by him and has installed a suitable corruption prevention system, the Principal/Owner may, at its own discretion, revoke the exclusion prematurely.

Article 5: Equal Treatment of all Bidders/Contractors/Subcontractors

- 1) The Bidder(s)/Contractor(s) undertake(s) to demand from all subcontractors a commitment in conformity with this Integrity Pact. The Bidder/Contractor shall be responsible for any violation(s) of the principles laid down in this agreement/Pact by any of its Subcontractors/sub-vendors.
- 2) The Principal/Owner will enter into Pacts on identical terms as this one with all Bidders and Contractors.
- 3) The Principal/Owner will disqualify Bidders, who do not submit, the duly signed Pact between the Principal/Owner and the bidder, along with the Tender or violate its provisions at any stage of the Tender process, from the Tender process.

Article 6- Duration of the Pact

This Pact begins when both the parties have legally signed it. It expires for the Contractor/ Vendor 12 months after the completion of work under the contract or till the continuation of defect liability period, whichever is more and for all other bidders, till the Contract has been awarded.

If any claim is made/lodged during the time, the same shall be binding and continue to be valid despite the lapse of this Pacts as specified above, unless it is Discharged/determined by the Competent Authority.

Article 7- Other Provisions

- 1) This Pact is subject to Indian Law, place of performance and jurisdiction is the **Head quarters of the Division** of the Principal/Owner, who has floated the Tender.
- 2) Changes and supplements need to be made in writing. Side agreements have not been made.
- 3) If the Contractor is a partnership or a consortium, this Pact must be signed by all the partners or by one or more partner holding power of attorney signed by all partners and consortium members. In case of a Company, the Pact must be signed by a representative duly authorized by board resolution.
- 4) Should one or several provisions of this Pact turn out to be invalid; the remainder of this Pact remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 5) It is agreed term and condition that any dispute or difference arising between the parties with regard to the terms of this Integrity Agreement / Pact, any action taken by the Owner/Principal in accordance with this **Integrity Agreement/ Pact or interpretation thereof shall not be subject to arbitration.**

Article 8- LEGAL AND PRIOR RIGHTS

All rights and remedies of the parties hereto shall be in addition to all the other legal rights and remedies belonging to such parties under the Contract and/or law and the same shall be deemed to be cumulative and not alternative to such legal rights and remedies aforesaid. For the sake of brevity, both the Parties agree that this Integrity Pact will have precedence over the Tender/Contact documents with regard any of the provisions covered under this Integrity Pact.

IN WITNESS WHEREOF the parties have signed and executed this Integrity Pact at the place and date first above mentioned in the presence of following witnesses:

.....
(For and on behalf of Principal/Owner)

.....
(For and on behalf of Bidder/Contractor)

WITNESSES:

1.
(signature, name and address)

2.
(signature, name and address)

Place: dated

FORM OF EARNEST MONEY (BANK GUARANTEE)

WHEREAS, contractor..... (Name of contractor) (hereinafter called "the contractor") has submitted his tender dated (date) for the construction of (name of work) (hereinafter called "the Tender")

KNOW ALL PEOPLE by these presents that we (name of bank) having our registered office at (hereinafter called "the Bank") are bound unto

(Name and division of Executive Engineer) (hereinafter called "the Engineer-in-Charge") in the sum of Rs.

..... (Rs. in words) for which payment well and truly to be made to the said Engineer-in-Charge the Bank binds itself, his successors and assigns by these presents.

SEALED with the Common Seal of the said Bank this day of 20.... .

THE CONDITIONS of this obligation are:

(1) If after tender opening the Contractor withdraws, his tender during the period of validity of tender (including extended validity of tender) specified in the Form of Tender;

(2) If the contractor having been notified of the acceptance of his tender by the Engineer-in-Charge:

(a) fails or refuses to execute the Form of Agreement in accordance with the Instructions to contractor, if required;

OR

(b) fails or refuses to furnish the Performance Guarantee, in accordance with the provisions of tender document and Instructions to contractor,

OR

(c) fails or refuses to start the work, in accordance with the provisions of the contract and Instructions to contractor,

OR

(d) fails or refuses to submit fresh Bank Guarantee of an equal amount of this Bank Guarantee, against Security Deposit after award of contract.

We undertake to pay to the Engineer-in-Charge up to the above amount upon receipt of his first written demand, without the Engineer-in-Charge having to substantiate his demand, provided that in his demand the Engineering-Charge will note that the amount claimed by him is due to him owing to the occurrence of one or any of the above conditions, specifying the occurred condition or conditions.

This Guarantee will remain in force up to and including the date* after the deadline for submission of tender as such deadline is stated in the Instructions to contractor or as it may be extended by the Engineer-in-Charge, notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank not later than the above date.

DATE

SIGNATURE OF THE BANK

WITNESS

SEAL

(SIGNATURE, NAME AND ADDRESS)

*Date to be worked out on the basis of validity period of 6 months from last date of receipt of tender

Form of Performance Security (Guarantee)

Bank Guarantee Bond

In consideration of the President of India (hereinafter called "The Government") having offered to accept the terms and conditions of the proposed agreement between.....and

(hereinafter called "the said Contractor(s)") for the work..... (hereinafter called "the said agreement") having agreed to production of an irrevocable Bank Guarantee for Rs.

(Rupees only) as a security/guarantee from the contractor(s) for compliance of his obligations in accordance with the terms and conditions in the said agreement.

1. We, (hereinafter referred to as "the Bank") hereby undertake to pay to the Government an amount not exceeding Rs. (Rupees..... Only) on demand by the Government.

2. We,(indicate the name of the Bank) do hereby undertake to pay the amounts due and payable under this guarantee without any demure, merely on a demand from the Government stating that the amount claimed as required to meet the recoveries due or likely to be due from the said contractor(s). Any such demand made on the bank shall be conclusive as regards the amount due and payable by the bank under this Guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs. (Rupeesonly)

3. We, the said bank further undertake to pay the Government any money so demanded notwithstanding any dispute or disputes raised by the contractor(s) in any suit or proceeding pending before any court or Tribunal relating thereto, our liability under this present being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment thereunder and the Contractor(s) shall have no claim against us for making such payment.

4. We, (indicate the name of the Bank) further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said agreement and that it shall continue to be enforceable till all the dues of the Government under or by virtue of the said agreement have been fully paid and its claims satisfied or discharged or till Engineering-Charge on behalf of the Government certified that the terms and conditions of the said agreement have been fully and properly carried out by the said Contractor(s) and accordingly discharges this guarantee.

5. We, (indicate the name of the Bank) further agree with the Government that the Government shall have the fullest liberty without our consent and without affecting in any manner our obligation hereunder to vary any of the terms and conditions of the said agreement or to extend time of performance by the said Contractor(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by the Government against the said contractor(s) and to forbear or enforce any of the terms and conditions relating to the said agreement and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Contractor(s) or for any forbearance, act of omission on the part of the Government or any indulgence by the Government to the said Contractor(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

6. This guarantee will not be discharged due to the change in the constitution of the Bank or the Contractor(s).

7. We, (indicate the name of the Bank) lastly undertake not to revoke this guarantee except with the previous consent of the Government in writing.

8. This guarantee shall be valid up tounless extended on demand by the Government. Notwithstanding anything mentioned above, our liability against this guarantee is restricted to Rs. (Rupees) and unless a claim in writing is lodged with us within six months of the date of expiry or the extended date of expiry of this guarantee all our liabilities under this guarantee shall stand discharged.

Dated theday offor.....(indicate the name of the Bank)

NAME OF WORK: Work:- “Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri..

TECHNICAL SPECIFICATIONS

- 01 All hardware items such as screws, G.I wires etc. Which are essentially required for completing on item as per specification will be deemed to be included in the item even when the same have not been specifically mentioned.
- 02 All hardware materials such as nuts/bolts/screws/washers etc to be used in the work shall be zinc/cadmium plated iron.
- 03 Any conduit which is not be wired by the contractor shall be provided which G.I fish wire for wiring by the same other agency subsequently. Nothing extra shall be paid.
- 04 While laying conduit, suitable junctions boxes shall left for pulling the wires.
- 05 Copper wire shall be FRLS PVC insulated multi-stranded conductors. Termination of multi stranded conductors shall be done using crimping type thimbles at both ends. Nothing extra shall be paid for the same.
- 06 The makes of material have been indicated in the list of acceptable makes. No other makes will be acceptable. The material to be used in the work shall be got approved from the Engineer-in-charge before its use at site. The Engineer in charge shall reserve the right to instruct the contractor to remove the material which, in his opinion, in not as per specification.
- 07 The proof of purchase in the form of invoice /cash/memo, of all the major components such as cables, wires, fittings, MCB DB's Geysers, exhaust fans etc. Shall have to produced by contractor at the time of final bill or as and when demanded by the departments.
- 08 Test report of all the XLPE insulated PVC sheathed armoured power cables used at site of work shall have to be submitted by the contractor at the time of submission of final bill.
- 09 Where switches/sockets/telephones outlet are to be , the same shall be of only make.
- 10 The MCB distribution boards shall be factory fabricated in the manufacturer of the MCB's of any of the makes specified and the same shall be duly pre-wired in the works. The board shall be brought to site in ready for installation condition. The MCBs and the MCB distribution board shall be of the same make.
- 11 The earthing shall be carried out in the presence of the Engineer-in-charge or his authorized representative.
- 12 All fitting/fans will be earthed as per specifications.

ADDITIONAL SPECIFICATIONS (INTERNAL E.I)

- 01 The work shall be carried out strictly in accordance with CPWD specification for electrical work Part-I internal 2013 and 1995 (external) as amended up to date and in accordance with Indian electricity Rules 1956, Indian electricity Act , 2003 as amended up to date and as per instructions of the Engineer-In-Charge including as below and nothing will be paid extra.
- 02 All materials to be used o this work by the contractor shall be got approved form the Engineer-In Charge and department. Has right to inspect the materials at manufacturer place before installation at site.
- 03 The work shall be carried out according to approved drawing/details which shall be subsequently issued to the successful for execution of work and as per instructions of the Engineer-In-Charge who will have the right to change out the layout as per requirement at site and the contractor shall not have any claim due to change in layout.
- 04 All damages done to the buildings, roads, pathways, floors, wall during the execution of electrical work shall be the responsibility of the contractor and the same will be made good immediately at his own cost to the satisfaction of the Engineer-In-Charge . Any expenditure incurred by the Engineer-In-Charge about recovery shall be the final.

- 05 The bad workmanship will not be accepted and defects shall be rectified at contractors cost of satisfaction of the Engineer-In-Charge. The program of the electrical work are to be coordinated in accordance with the building work and no claim for idle labor will stipulated in the tender, electrical work shall have to be completed within ____ days of the completion of the civil work.
- 06 All the debris of the electrical works should be removed and the site should be cleared by the contractor immediately after the accruing of debris. Similarly any rejected materials should be immediately cleared off from the site by the contractor.
- 07 Issue of materials to the contractor whoever stipulated, shall be according to the requirement at site from time to time depending upon the progress of the work.
- 08 Cement for this bonafied work is to be arranged and used by the contractor himself and nothing extra will be paid on this account.
- 09 The contractor of his representative is bound to sign the site order book as and when required by the Engineer-In-Charge and to comply with the remarks.
- 10 The size of conduit and wiring shall be got approved from the Engineer-In-Charge before taking up to the execution.
- 11 The contractor shall make his own arrangement at his own cost for electrical/general tools and plants required for the work.
- 12 Main board and main distribution board: The work shall be carried out according to the drawing /details as approved by the Engineer-In-Charge. The contractor shall have to get the samples approved before the whole lot is brought to site and it shall include al the interconnections etc.
- 13 No central/state sale tax/GST/Contract tax/excise duty etc. Shall be separately paid by the department. The rates should be inclusive of all taxes and duties (exclusive of service tax) Deduction of contract tax at source shall be made while releasing payment through running/final bill as applicable. A certificate specifying the rates and amount of deduction shall however to be issued. No form –D 31/32 (road permit) shall be issued by the department. The road permit shall be arranged by the tendered by the renderer on his own.
- 14 The entire installation shall be at the risk and responsibility of the contractor shall be at the risk and responsibility of the contractor until these are tested and handed over to the department. However there is any delay in construction from the department side, the installation may be taken over in parts, but the decision on the same shall rest with Engineer-In-Charge which shall be binding on the contractor.
- 15 No withstanding the schedule of quantities, all items of interrelated works considered necessary to make the installation complete and operative deemed to be included shall be provided by the contractor at extra at extra cost.
- 16 The connection interconnection, earthing and inter earthing shall be done by the contractor wherever required and nothing extra shall be paid on this account.
- 17 Some of the items of the work, if already executed: on the case the successful renderer shall required shall be used by the contractor. The recovery will made for these items as accepted rate of other agencies.
- 18 Nothing extra shall be paid for :- a) Inter connection with thimbles /wires /tapes etc.
- 19 The competent authority reserve to himself the right of accepting the whole or any part of the quotation shall be bound to perform the rate quoted.

ADDITIONAL TERMS AND CONDITIONS FOR ELECTRIC WORKS

1. The work shall be carried out as per CPWD specifications for Electrical Work internal 2013 and external 1994) ,sub-station amended up to date & manufacturer specifications and laid down instruction in CPWD works Manual 2019 & SOPs.
2. All the dismantle material will be the property of BSF and same will be deposited by the contractor to JE (Elect).
3. The make of MCCB shall be GE/ Schneider/L&T/ABB. The decision of Engg in charge in regard to use of any particular make out of mentioned brands as per manufacturer specifications shall be binding to contractor.
**Scheinder -CVS -Breaking Capacity (KA) ICU as per IEC 60947-
L&T –D-sine DU/DH- Breaking Capacity (KA) ICU as per IEC 60947-2
ABB-as per manufacturer specifications**
4. The price quoted shall be net and inclusive of all type of taxes.
5. Taxes as applicable will be deducted in the bill as per latest provisions of Govt. of India.
6. The work is required to be executed in restricted area and the contractor shall abide by the instructions/written directive of BSF officials regarding working hours and entry in the building/area. No claim shall be entertained on this account.
7. All material to be provided at site shall have to be got approved from Engineer-in-charge before use at site. The decision of the Engineer in charge in regard to use of any particular brand/make shall be final and binding on the contractor.
8. No road cutting will be done without approval of Engg in charge. Digging of soil below the road will be done without cutting the road and making the space for laying of cable protection pipe of required size.
9. Only specified material will be utilized in the work. Any inferior work shall be summarily rejected.
10. Wherever required by the Engineer-in-Charge , the material shall be got tested by the supplier and all charges like packing/testing etc shall be borne by the supplier only.
11. Any damage done to the installation during execution of work shall be responsibility of the contractor and shall have to be repaired free of cost.
12. Any serviceable item within the dismantle material will be the property of the deptt.
13. The material can also be inspected at the manufacturer premises as per direction of Engineer-in-Charge/ department. The contractor will intimate the date of inspection to the department.
14. The original test certificate of tests carried out by the manufacturer will be submitted by contractor/firm if required by the department.
15. Drawing of the panels shall be approved by the Department before fabrication and will be submitted by the contractor.
16. Panel/Joint box shall be manufactured by CPRI approved manufacturer and inspection of the board will be carried out by department at manufacturer premises.
17. The material shall be supplied at site for which no transportation charges and road permit will be issued by the Department.
18. Material to be supplied should be as per the CPWD electrical and manufacturer's specification. BIS specification and IS code specify for the material to be supplied be followed otherwise it will not be accepted and will be replaced by the contractor at his own risk and cost.
19. Each panel should have danger notice plate on the bus bar.
20. Contractor will submit the detail of measurement of cable to be laid along with the drawing for approval by Engg in Charge before starting the work and on completion of work before preparing the bill.
21. All the test reports required for wiring/earthing work as per internal specification and substation work will have to be submit by the contractor as and when desired by Engg in charge.
22. Contractor will submit the computerized sketch diagram of complete rewiring showing the main and distribution panels, new UG cable laid sketch diagram with size of cable after completion of work. Nothing shall be paid on account of this.
23. Manufacturer Warrantee/guarantee card applicable to the material to be provided against the work will be submitted along with the bill by the contractor/supplier.
24. No advance payment shall be made to the firm.

25. The contractor will give six month Warrantee/guarantee of the material (except those whose warranty/guarantee already prescribed by the manufacturer/company) to be used in the work from the date of completion for any manufacturing defect and will replaced the defective items/parts free of cost during said period.
26. Contractor will be bound to accept all the decisions require to be taken by the Engg. In charge during execution of work.
27. The contractor may be asked to submit the copy of the bill regarding purchase of material from manufacturer or authorized stockiest of manufacturer as well as submit the genuineness certificate if required by department .
28. Rates quoted by contractor should be inclusive of rates of dismantling the existing item. Nothing shall be paid extra on account of this.
29. Contractor will provide the guarantee card/ certificate of LED fitting issued by the manufacturer for the period of minimum two years to department before preparation of bill.
30. The material can also be inspected at the manufacturer premises.

31. The original test certificate of cable tested carried out by the manufacturer shall also be submitted by the contractor.
32. The material shall be supplied at site for which no transportation charges toll tax, road permit will be paid by the Department.
33. The make of material not mentioned should be as per BIS.
34. Contractor will submit the detail of measurement of work carried out to JE(E) for verifying at site & preparation of bill.
35. Competent authority reserves the rights to accept/reject any tender without any intimation.
36. Lowest rates offered by contractor/supplier will be valid for six month from the date of issue of award of work.
37. If the category and product code of material to be used in the manufacturer latest price list changes the contractor will be bound to provide the material as per the price list in vogue and decision of Engg in charge with regard to make will be final and binding to the contractor
38. Security as applicable per the terms and condition will be deducted in the bill.
39. The rates quoted by firm for each item in the schedule shall be inclusive of dismantling the existing item. No extra charges will be paid on account of this.
40. Contractor will be responsible for any injury/accident and safety of labour deployed by him. All the safety equipment's (as per electricity rules) required while execution of work will be given by the contractor to labour & nothing shall be paid extra on account of this.
41. Contractor will survey the site before starting the work and submit the measurement of material/inventory of work required/cable required for execution to AE/JE before start of work. Any material brought by the contractor at site without measurement / bringing into the notice of Engg in charge will not be payable.
42. Contractor will give demonstration of the indoor/outdoor electrical fixtures (where necessary as per requirement of the department) of the requisite make and model mentioned in the schedule at site and fix the material only after observing all the technical parameters and up to satisfaction of Engg in charge.
43. Wherever required by the Engineer-in-Charge , the work/fabricated material shall be got tested by the contractor at Govt Lab and all for testing charges shall be borne by the contractor only.
44. The old panel will be dismantled by the contractor free of cost and material will be deposited to JE Store
45. All relevant codes as per electricity rules for execution of work will be followed.
46. The incoming/outgoing locations should be marked on the panel. No charges will be paid to contractor in this regard.
47. If any Lock down announced by Govt of India/State Govt/BSF due to pandemic condition such as Covid-19 at present or any other and work remain suspended, nothing shall be paid to contractor during this period.
48. Labour to be engaged in work should have medical fitness certificate if required by the department. The contractor will also follow the guideline issued by Govt of India/State Govt during any pandemic and will follow the safety norms and be responsible for the safety of labours to be engaged in the work. No claim for any causality in this regard will be entertained.
49. If any make and model as specified in the NIT is not available in the market, contractor will submit non availability of material certificate from manufacturer and provide equivalent make & model having technical specification, rate at par with specified model only after approval of Engg- in- charge.

ADDITIONAL CONDITION OF CONTRACT

1. The work shall be carried out as per MNRE/CPWD specifications Part-I (Internal) 2013 Part-II External 2005, amended up to date & as per additional specifications & conditions for this work& as per CPWD sub - station specifications 2013 and Electrical Work specification internal (Part - I 2007,2013-14 and external 1994) and sub - station amended up to date .
2. The department reserves the right to send such materials to the manufactures authorized test laboratory to verify the genuineness & quality of the product.
3. **The contractor is advised to visit the site before quoting for this tender to apprise himself about the site environments & other condition. The contractor should see the site and understand the work requirements, the condition in regard to accessibility of site and nature of ground, working condition including stacking of materials, installations of T & P etc. conditions affecting accommodation and movement of labour etc and in case of doubt, obtain required particulars, which may in any way influence his tender, from the BSF as no claim whatsoever will be entertained for any alleged ignorance thereof Before submitting the tender, the contractor should visit the site and satisfy himself as to the conditions prevalent there**
4. **Time is the essence of the Contract. Any piece meal work may also require completing in odd hours in order to restore electrical supply as per requirement of department/for ongoing activities for preparation of flight. If such work arises it will be sole responsibility of contractor to get done the work in given time. The rates shall be inclusive of all such eventualities as well as of all taxes, levies, packing, transportation .handling etc .Nothing extra shall be paid. The contractor shall be responsible for getting all approvals and clearance about labour passes etc as well as all the effort in this connection should be in the preview of contractor. No claim of the contractor shall be entertained by the department for the idle labour.**
5. The contractor shall be responsible for any damage done to the building of electrical installations during the execution of the work. Damage, if any shall have to be made good by the contractor at his own cost otherwise the same shall be got rectified made good at the risk & cost the contractor.
6. The work shall be carried out engineering like manner & bad workmanship shall be rejected summarily. For redoing the job, no claim of the contractor shall be entertained on this account.
7. The site shall be cleared of malba, debris caused by working at site by the electrical contractor without any extra cost to the department.
8. The contractor or his authorized representative shall sign the site order book & comply with the remarks entered therein by the representative of the department
9. **The Client is not concerned with any rise or fall in the prices of any materials. The rates quoted shall include all costs, allowances, taxes/levies/cess or any other charges including any enhanced labour rates etc., which may be enacted from time to time by the State and/or Central Government.**
10. The contractor will ensure that all the skilled persons deployed for executing the electrical work possesses the wireman license issued by approved authorities. Consequences arising due to the default of the contractor to comply with this condition would be contractor's responsibility only.
11. The contractor will make his own arrangement for storage of his material. If issued to him departmentally, the material shall be issued to him from JE (E)"s store. The watch & ward of the materials & of the installations would be responsibility of contractor till the work is completed and handed over to the department. Nothing extra shall be paid to the contractor on this account.

12. The contractor shall make his own arrangement for carriage of materials, fittings, cables etc required for execution of work/issued to him departmentally from the site of work at his own cost. Nothing extra shall be paid on this account.
13. All the DB's switchgears shall have identification marking on them written in white paint. Nothing extra shall be paid on this account.
14. Earth points with studs are to be provided on each of the switch boards/ DB's
15. The drawings showing layout of the main board, allied equipment shall be got approved by the contractor from the Engineer-in-charge before fabrication & execution.
16. All hardware, fastening material viz, nuts, bolts, washers & screws etc to be used on work shall be of zinc and cadmium plated iron.
17. The contractor shall have to furnish the insulation test report, earth report, along all required details of electrical load on the prescribed Performa for the electric connection from Supply Company as reqd.
18. The contractor shall submit the completion certificate & completion plan as per clause 2.30 (AppendixF) of General specifications for Electrical works Part-I Internal 2013.
19. All concealed work & earthing shall have to be done in the presence of Engineer-in-charge or his authorized representative.
20. A list of approved make of materials to be used in the work is appended as Annexure-I. The contractor should use only the approved makes of materials in the work specified in the Annexure-I. The make of MCB DB should be same as of MCB.
21. The quoted rates shall be inclusive of all taxes such as GST, WCT, E-Cess & Cess etc. & nothing extra shall be paid on this account.
22. Only FRLS wires up to 1100V. Grade shall be used in wiring.
23. Thimbles, lugs are to be provided whenever required by the contractor without any extra cost.
24. Loop earthing wire-in place of bare copper wire green/yellow insulated copper wire to be used as per CPWD specification Part-I (Internal) 2013.
25. Proper temporary connections shall have to be provided for maintaining electrical supply to the building during the progress of work, without any extra cost with no hindrance to work of repair maintenance of Solar power plant.
26. The work will also be carried out at different locations in piecemeal manner, as and when required.
27. The contractor will ensure the disbursement of wage and documentary evidence paper shall be submitted along with bill by AE (E) while submitting in Division office.
28. Nothing extra will be paid on account of Sales tax/Excise, GST/Turnover Tax or any other Taxes.
29. **Any balance items, which are not explicitly spelt out here, but are required for the completeness of the work, shall also be included in bidder's scope.**
30. The Client is not concerned with any rise or fall in the prices of any materials. The rates quoted shall include all costs, allowances, taxes/levies/cess or any other charges including any enhanced labour rates etc which may be enacted from time to time by the State and/or Central Government.
31. The original test certificate of Transformer/VCB / cable tested carried out by the manufacturer shall also be submitted by the contractor

SCOPE OF WORK & TECHNICAL SPECIFICATIONS

The Scope of work of project for Contractor includes Design, Supplying, Installation, Testing and Commissioning of 25 KWp Solar PV Plant & Alternative Lighting Arrangement for 01 BOP of 06 Bn and 01 BOP of 40 Bn BSF as per site condition, including 5 years onsite maintenance & warranty.

1.0 INTRODUCTION:

Border Security Force (BSF) through this tender intends to establish 25 KWp Solar PV Plant with minimum six hour battery back-up for 02 BOPs under various SHQ of BSF to utilize solar energy efficiently. The aim of the project will be to utilize latest technology to harness power from sun, maintain and continuously monitor the performance of the system. Hence efficient solar panel in market is envisaged for the system.

2.0 PROPOSED SITE LOCATIONS:

BOP's are located mostly in the remote border areas of West Bengal (Chandani and Sighpara).

Please note that site locations are at 01 BOP of 06 Bn and 01 BOP of 40 Bn BSF under SHQ BSF Jalpaiguri.

3.0 SCOPE OF WORK & TECHNICAL SPECIFICATION:

3.1 The bidder should note that the specifications furnished in the tender is of general nature only and it is the responsibility of the bidder to design, supply, install, commission and put in operation of the equipment and services required for the satisfactory performance of the solar PV power Plant.

3.2 The scope of this specification shall cover study of site condition and based on that design, engineering, manufacture, shop testing, inspection at site and plant, packing & forwarding, transportation up to project site, loading & unloading, storage in safe custody, erection, carrying out preliminary tests at site, commissioning, performance testing of solar photovoltaic power plant and connecting the plant with all existing buildings at the site with associated components and handing over to the BSF all the equipment installed including 5 years maintenance & warranty from the date of Handing over and an additional warranty (by manufacturer) as specified in conditions of contract.

3.3 Each 25 KWp solar PV power plant systems shall be complete with following items:

a) Solar PV modules to achieve total capacity of 25KWp (minimum 350 Watt solar panel)- Made in India, Mono/poly Crystalline silicon solar cells as per latest Ministry of New and Renewable Energy (MNRE) specifications/ relevant Bureau of Indian standard codes (BIS) specifications/latest edition of IEC SPECIFICATIONS and make of the module should be as per MNRE approved vendors list. Minimum cell efficiency shall be as per latest MNRE standard.

The PV modules must conform to the latest edition of any of the following IEC/ equivalent BIS Standards for PV module design qualification and type approval:

Crystalline Silicon PV module: IEC 61215/IS14286

In addition, the modules must conform to IEC 61730 Part-1- requirement for construction & part-2- requirement for testing, for safety qualification or equivalent IS (Under Dev.)

If PV modules to be used in a highly corrosive atmosphere (coastal areas, etc.) must qualify Salt Mist Corrosion Testing as per IEC61701/IS61701

The amount of power they produce is roughly proportional to the intensity and the angle of the light reaching them. They are therefore required to be positioned to take maximum advantage of available sunlight within string constraints. Bidder will position the PV modules in such a manner that the maximum power is obtained with the sun's movements during the day. PV modules and associated accessories shall be suitable for continuous outdoor use and withstand with weather condition of the particular site location.

Module deployed must use a RF identification tag as per latest MNRE specifications. Protective devices against surges at the PV module shall be provided. Low voltage drop bypass diodes shall be provided.

PV Module must be tested and approved by one of the IEC authorized test centre.

Module frame shall be made of corrosion resistant materials, preferably having anodized aluminium.

b) Battery bank

LMLA(Tall Tubular Solar Battery 12 Volt battery type C 10) /VRLA tubular Gel/SMF Type suitable for 25 KWP solar plant to provide minimum 6 hrs power backup on full load shall be as per relevant Bureau of Indian standard codes (BIS) specifications/ latest Ministry of New and Renewable Energy (MNRE) specifications/ conform to latest edition IEC and make of the battery should be as per MNRE approved vendors list along with Appropriate cabinets for battery banks, with the provision of racks for batteries should also be done if required; battery room (control room) adequate size with proper ventilation shall have to be prepared. The batteries shall be designed for operating in ambient temperature of the particular site. Battery bank connection to the PCU is taken through proper protection for preventing damage to the batteries.

c) Module Mounting structures (MMS)

MMS shall be as per site condition and shall be so designed to withstand the speed of the wind zone of that particular location (minimum design wind speed of 170 KM/ Hour), clamps and accessories ,necessary civil works, as per relevant Bureau of Indian standard codes (BIS) specifications/ Ministry of New and Renewable Energy (MNRE) specifications. Each structure should have angle of inclination as per the site condition to take maximum isolation. However to accommodate more capacity the angle inclination may be reduced until the plant meets the specified performance. It must be ensured that the design has been certified by recognized lab/Institute in this regard and submit wind loading sheet to BSF. Suitable fastening arrangement such as grouting and calming should be provided to secure the installation against the specific wind speed. The PV array structure design shall be appropriate with a factor of safety of min. 1.5. The structure shall be designed to withstand operating environmental conditions for a period of minimum 25 years.

Civil Work for Module Mounting Structure in flood prone area and other locations as per site requirement & as per the instruction of Engineer in Charge:- Foundation shall be provided considering the flood prone area and structure should be designed to save guard against the flood, with providing the RCC footing like piling/raft footing etc. and columns to be braced with beam at top column as per structural design/site requirement. Contractor shall be totally responsible against the any damage occurs to the structure due to flood and natural climate like tornado etc. The height of the base of module shall be as per Drawing.

The total load of the structure(when installed with PV modules) on the terrace should be less than 60kg/m², approved structural engineers should certify after the building inspection that the building on which PV plant is to be installed is able to take such loads. The total responsibility is with contractor to check and verify the same. Installation of grid structure for solar PV mounting should not tamper with the water proofing of roofs. In the event of any seepages/leakages, contractor has to rectify with standard water treatment mechanism to the satisfaction of BSF.

Array/module/panels support structure shall be fabricated using corrosion resistant hot dip galvanized with minimum thickness of coating not less than 80 micron on each side. The mounting structure steel shall be as per latest

IS2062:1992 and galvanization of the mounting structure shall be in compliance of the latest IS 4759, 2629, 4736 as applicable.

Structure material shall be corrosion resistant and electrolytic ally compatible with the materials used in the module frame, its fasteners, nuts and bolts.

Page 33

The ground mounting structure design must follow the existing land profile. The proper clearance between lower edge of PV panel and ground level shall be maintained for allowing proper ventilation for cooling , also ease of cleaning and maintenance of panel. The PV panel structures shall be designed in such a way that cleaning of the panels shall be carried out safely.

Each PV panel structures shall incorporate one bird repellent spike at a level higher than the panel edge. The location of the spike should be selected for minimum shadow effect.

All fasteners should be primarily stainless steel to resist corrosion. The support structure shall be free from corrosion when installed.

PV modules shall be secured to support structure using screw fasteners and /or metal clamps. Screw fasteners shall use existing mounting holes provided by modules manufacturer, adequately treated to resist corrosion.

Adequate spacing shall be provided between any two modules secured on PV panel for improved wind resistance.

The grid structure should be installed in manner to leave sufficient space for repair and maintenance aspect of the roof top, particularly for leakages.

d) Solar Inverters/ Power Conditioning Unit

The capacity shall be 25 KVA (Suitable for 25 KWP solar plant), programmable, smart inverter, Hybrid /off grid (with provision to charge the battery from main source), hybrid as per relevant Bureau of Indian standard (BIS) codes (IEC 61683/IS 61683 & IEC 60068-2(1,2,14,30)) specifications/ Ministry of New and Renewable Energy (MNRE) specifications.

Power Conditioning Unit (PCU)

As SPV array produces direct current (DC) and it is necessary to convert this to alternating current (AC) and adjust the voltage levels before powering equipment designed for nominal mains AC supply. Conversion shall be achieved using an electronic inverter and the associated control and protection devices. All these components of the system are termed the Power Conditioning Unit or simply the PCU. In addition, the PCU shall also house MPPT (Maximum Power Point Tracker), to maximize Solar PV array controller and inverter and shall be supplied as integrated unit or different units of charge controller and inverter depending on rating & size of the power plant.

Maximum Power Point Tracker (MPPT) :

Maximum Power Point Tracker (MPPT) shall be integrated into the PCU to maximize energy drawn from the SPV array. The MPPT should be Microprocessor / Microcontroller based to minimize power losses.

CHARGE CONTROLLER:

DC electricity from the array is used to feed inverter as well as charge the battery bank for night time use. The total energy received from the array being dependent upon the availability of sunshine during the day which in turn varies from season to season; there may be occasions when the Power Plant generates surplus energy. Similarly in monsoon season, prolonged overcast sky could Battery Bank getting drained beyond the maximum allowed depth of discharge (DOD). To guard against battery overcharge or deep discharge, the charge controller shall be incorporated by the contractor.

INVERTER:

Inverter shall be hybrid inverter/ off grid based on PWM technology. It must have built-in meter and data logger to monitor plant performance through external computer. The DSP controller is used for controlling the whole unit in quick time. Rating of the inverter is suitable for 25 KWP plant, suitable D.C./AC voltage rating, pure sine wave inverter with inbuilt MPPT Charge controller with the output power of 25 KWP. The output voltage wave is good quality sine wave. External battery charging facility through AC is also to be provided.

e) Junction boxes (JBs) shall be as per equivalent BIS Standard, IP 65 (for outdoor use) and IP 54 (for indoor use)

The junction boxes are to be provided in the PV array for termination of connecting cables. The JB's shall be made of GRP/FRP/Powder Coated Aluminium /cast aluminium alloy with full dust, water & vermin proof arrangement. All wires/cables must be terminated through cables lugs. The JB's shall be such a way that the input & output terminated can be made through suitable cable glands. Copper bus bars/terminal blocks housed in the junction box with suitable termination threads conforming to IP65 standard and IEC 62208 Hinged door with EPDM rubber gasket to prevent water entry. Single /double compression cable glands. Provision of earthings. It should be placed at feet height or above for ease of accessibility.

Each Junction Box shall have High quality suitable capacity Metal Oxide arrestors (MOVs)/SPDs, suitable Reverse Blocking Diodes. The Junction Boxes shall have suitable arrangement monitoring and disconnection for each of the groups. Suitable markings shall be provided on the bus bar for easy identification and the cable ferrules must be fitted at the cable termination points for identification.

f) AC/DC DISTRIBUTION BOARD: shall be as per equivalent BIS Standard/ latest MNRE specification. DC Distribution panel shall receive the DC output from the array field. DC DPBs shall have sheet from enclosure of dust & vermin proof conform to IP 65 protection. The bus bars shall be made of copper of desired size. Suitable capacity MCBs/MCCB shall be provided for controlling the DC power output to the PCU along with necessary surge arrestors.

AC DISTRIBUTION PANEL BOARD:

AC Distribution Panel Board (DPB) shall control the AC power from PCU/inverter, and should have necessary surge arrestors. **Interconnection from ACDB to mains at LT Bus bar of exiting building through proper size cable.**

All switches and the circuit breakers, connectors should conform to IEC 60947, part I, II and III/IS60947 part I, II and III.

The changeover switches/panels, cabling work should be undertaken by the contractor as part of the project.

All the Panel's shall be metal clad, totally enclosed, rigid, floor mounted, air-insulated, cubical type suitable for operation on three phase/single phase, 415 or 230 volts, 50 Hz.

The panels shall be designed for minimum expected ambient temperature of 45 degree Celsius, 80 percent humidity and dusty weather.

All indoor panels shall have the protection of IP54 or better. All outdoor panels shall have the protection of IP65 or better.

It should conform to Indian Electricity Act and rules (till last amendment).

All the 415 AC or 230 volts devise/equipment like bus support insulators, circuit breakers, SPDs, VTs etc. mounted inside the switchgear shall be suitable for continuous operation and satisfactory performance under the following supply conditions

g) Cables shall be as per relevant Bureau of Indian standard codes (BIS) Std. (IEC 60227/IS 694 & IEC 60502/ IS1554 (Pt. I&II)/Ministry of New and Renewable Energy (MNRE) specifications.

All cables/wires shall be routed in a G.I. Cable tray/raceway/conduit suitably tagged and marked with proper manner by good quality ferrule or by other means so that cable easily identified.

Power Cables of adequate rating shall be required for interconnection of:

- Modules/panels within array
- Array & DCDB
- DCDB /inverter/Battery bank
- Inverter & ACDB & Interconnection of existing buildings with ACDB/SOLAR PV Plant
- Any other cable as per site requirement

The cables shall be of 1100 volt grade, copper conductor, XLPE/PVC insulated, PVC sheathed, armoured and overall PVC sheathed, strictly as per IS: 7098 (Part I & II) – 1976 or IS 1554. Colour of the outer sheath shall be Black.

Power cables size for 1.1 kV systems shall be chosen taking into account the full load current & voltage drop. The allowable voltage drop at terminal of the connected equipment shall be max. 3% at full load. The debating factors viz. group duration of temp. duration shall also be considered while choosing the conductor size.

Control cables shall be FRLS type 1100 volts grade, copper conductor, PVC insulated, PVC sheathed, armoured and overall PVC sheathed, strictly as per IS: 1554 (Part I) and other relevant standards.

The permissible voltage drop from the SPV Generator to the Charge controller shall not be more than 1% of peak power voltage of the SPV power source (generating system). In the light of this fact the cross-sectional area of the cable chosen is such that the voltage drop introduced by it shall be within 2% of the system voltage at peak power.

All connections should be properly terminated, soldered and/or sealed from outdoor and indoor elements. Relevant codes and operating manuals must be followed. Extensive wiring and terminations (connection points) for all PV components is needed along with electrical connection to lighting loads.

The cable with suitable rating from PV module to inverter to battery bank, inverter to ACDB , ACDB to panel and panel to existing building etc. shall be provided by the bidder as per the site requirement. The rate shall be inclusive in the quoted amount in the bill of quantities. Nothing extra will be paid in this regard.

h) LIGHTNING PROTECTION

The SPV power plants and control room shall be provided with lightning & overvoltage protection. The main aim in this protection shall be to reduce the over voltage to a tolerable value before it reaches the PV or other sub system components. The source of over voltage can be lightning, atmosphere disturbances etc. The entire space occupying the SPV array and control room shall be suitably protected against Lightning by deploying required number of Lightning Arrestors. Lightning protected against induced high-voltages shall be provided by the use of suitable numbers of Early Streamer Emission air terminal(ESE) air terminal / conventional lightning protection and suitable maintenance free chemical earthing (Minimum 4 nos.) such that induced transients find an alternate route to earth.

SURGE PROTECTION

Internal surge protection shall consist of three MOV type surge – arrestors connected from +ve and –ve terminals to earth (via Y arrangement)

i) EARTHING PROTECTION

Each array structure of the PV yard shall be grounded/earthed properly as per IS:3043-1987. In addition the lightning arrester/masts shall also be earthed inside the array field. Earth Resistance shall be tested in presence of the representative of BSF as and when required after earthing by calibrated earth tester. PCU, ACDB and DCDB etc. shall also be earthed properly.

Earth resistance shall not be more than 5 ohms. It shall ensure that all the earthing points are bonded together to make them at the same potential.

j) Fire extinguishers, Danger Boards, rubber mat and Signage's

Danger boards should be provided as and where necessary as per IE Act./IE rules as amended up to date. Three signage shall be provided one in each at battery cum control room, solar array area, and main entry from BOPs. Text of the signage may be finalized in consultation with Engineer-in-charge/owner.

Firefighting system for the proposed power plant for fire protection shall be consisting of the following:

- a) Portable fire extinguishers in control room for fire caused by electrical short circuit
- b) Sand bucket in control room

The installation of fire extinguishers should conform to TAC REGULATIONS AND BIS standards. The fire extinguishers shall be provided in the control room housing PCUs as well as on the roof or site where PV array have been installed.

k) Control room for solar plant:

The size of control room of prefabricated Structure shall be of size 120 sq. feet (minimum), with head room of minimum 2.9 meters & plinth height shall be minimum 1.8 meter from natural ground level as per drawing and direction of Engineer-in-charge. The flooring should be of RCC (must withstand the load of batteries and other equipment). Steel gate must be installed in control room. Roof of control room must be so designed to prevent water lodging.

Following test must be conducted at each site during execution:

- 1- Compressive strength test for cube and brick.
- 2- Slump Test
- 3- Sieve Analysis of fine and course aggregate.
- 4- Silt content.
- 5- Fineness Modulus

The specifications shall be as per CPWD /IS standards and as per drawing and direction of Engineer-in charge.

The control room should be complete with internal electrification (as per CPWD specifications) which include following:

- ☐ Copper wiring with PVC conduit.
- ☐ Exhaust fan- 2 Nos.
- ☐ Ceiling Fan- 2 Nos.
- ☐ LED tube light- 2 Nos.
- ☐ LED Flood light (30-40 watt) -4 no. (for external illumination)
- ☐ 6/16 Amp. Switch socket – 2 Nos. each
- ☐ Sock proof rubber mat
- ☐ Fire Extinguisher

l) Contractor shall prepare the drawings for control room and get it approved from BSF before execution.

m) Electrical Load wiring/cabling for Existing Building:

Separate Electrical load wiring with PVC conduit shall be in the scope of contractor in all the existing BOPs buildings at the project site for solar PV plant supply including conducting, wiring, switch socket, MCB distribution boards, MCBs, interconnection cables of existing buildings with Solar PV Plant complete in all respect. The wiring should be as per latest CPWD specifications. Contractor shall also repair/replace existing switch sockets, plate etc. as per site requirement. Suitable rating MCBs with distribution boards to be used for electrical protection with proper earthing. The Contractor shall make arrangement for by-pass system/Changeover switches (Manual/automatic type with interlocking arrangement , MCCBs, Panels, Equipment's, switchgears and all other accessories as per actual requirement of site) so that power supply can be transferred easily without long duration/disruption. No extra cost will be paid to the contractor for the same.

Min. Size of wire for lighting ckt. – 1.5 sq. mm FRLS copper wire

Min. Size of wire for power ckt. – 4 sq. mm FRLS copper wire

Cable- XLPE Armoured /Un armoured as per requirement of suitable size.

Switch/socket – Modular/piano type with complete plate, box as per site requirement

Distribution Boards with MCBs- Double door single phase / three phase.

n) Levelling, Internal roads and paths including storm water drains for SOLAR PV plant shall be in the scope of contractor. Work shall be done as per CPWD/MNRE specifications, site condition and directions of Engineer-in- charge. No extra cost shall be paid for the same.

o) Any other equipments/ activities which are not specifically mentioned in this documents but necessary for safe and efficient operation of the SPV plant shall be executed by the contractor and no extra cost shall be paid for the same. Site Survey, Layout Planning & Drawings/Documents Before start of work contractor shall conduct survey of the site and

finalize the plant location, control room location layout planning and prepare the detailed design & drawings for the complete Solar PV Plant.

The Contractor shall furnish the following drawings after Award and obtain approval from BSF.

- a) General arrangement drawings and schematic drawings indicating all the specifications of hardware shall be provided to BSF before starting the installation. The installations shall be only as per the approved drawing of BSF.
- b) General arrangement and dimensioned layout Schematic Drawing showing the SPV panel and protection system including battery bank design and any logical control diagram as required.
- c) Control room drawings
- d) Array/Module mounting structure design calculation and drawing along with stand pro, It must be ensured that the design has been certified by recognized lab/Institute in this regard and submit wind loading sheet to BSF
- e) Item wise bill of material for complete SPV plant covering major components and associated accessories
- f) Overall layout showing SPV Plant
- g) Electrical schematic drawings with details/ specifications of components of 25 kWp solar power plant with battery bank.
- h) Manufacture's test certificates/ warranty certificates wherever applicable.
- i) Format for reports and charts for analysis of various parameters.
- j) All safety/ fire protection items as per specifications. Danger boards, warning boards, route marker etc. also to be provided as per statutory regulations. Format for annual maintenance and preventive maintenance and the maintenance activities are required.

3.4 Test Reports/Certificate

Contractor shall submit the test certificate/reports for items /components from any of the NABL/IEC Accredited testing laboratories or MNRE approved test centers. The list of MNRE approved test centers will be reviewed and updated from time to time.

Type test certificates for all the tests specified for the factory built Solar PV modules, and the component parts shall be submitted by the contractor.

Contractor shall furnish copies of the test reports for approval before dispatch.

Two sets of copies of the compiled and approved test certificates shall be submitted to the BSF.

3.5 Maintenance and warranty

The Standard Comprehensive Onsite Maintenance & Warranty will be valid for five years including battery bank, mechanical structures, electrical works, inverters, PV Module, charge controllers, maximum power point tracker units, distribution boards, digital meters, switch gear, and overall workmanship of SPV power plant. System must be warranted against any manufacturing / design/ installation defect.

Warranty period will start from the date of handing over of the site to BSF including testing and successfully commissioning of the work of Solar PV plant in all respect.

Warranty will be free of cost and nothing will be paid for repair/ replacement of defective parts /preventive maintenance or any other job on account of works required to execute during warranty period.

The contractor shall sign Service level Agreement (SLA) with BSF on Rs. 100/- stamp paper as per the standard format approved by BSF.

Contractor shall appoint State wise maintenance team and attend any defects within 24 hours. Original warranty certificate of equipment's (equipment's having more than 5 years warranty) shall be handed over to BSF after completion of 5 year warranty period.

3.6 The scope of supply shall also include comprehensive insurance of the products against theft/damage/defects and human beings involved against accidents up to completion of work and handing over. Storage & transportation is also in the scope of the contractor.

3.7 All the Electrical works shall be carried out as per the relevant codes and standards and as per the guidelines of prevailing Electrical inspectorate. All liaison work required for Electrical inspectorate approval shall be in the scope of the contractor and the rate quoted by the contractor shall be inclusive of the same. The contractor shall not claim any additional fee for liaison work and he shall prepare the all the necessary documents such as drawings as required for the approval & sanction order.

3.8 The civil works, if any, for the supports for SPV/ any chipping works and refinishing by plastering and painting for installation of complete system shall also be in scope of the contractor.

3.9 All the necessary co-ordination with regard to sub-contracted items shall be carried out by the Bidder. The purchaser/Engineer will communicate only with the Bidder for all matter pertaining to this contract.

3.10 The contractor shall be responsible for obtaining necessary statutory approvals / prior approvals, from Local bodies, Electrical Inspectorate, State Pollution Control Board, etc. if any as applicable. All MNRE guidelines for the material and installation should be followed by the bidders. Nothing extra shall be paid to the contractor for the same.

3.11 The total price quoted for this contract shall be all-inclusive basis and shall cover all items and service necessary for successful completion of the contract. All the fittings and accessories that might not have been mentioned specifically in the specification but are necessary for equipment's of the system, shall be deemed to be included in the specification and shall be supplied and furnished by the Contractor without any extra charge.

3.12 The power from Hybrid inverters shall be taken to a distribution panel with multifunction meters at outgoing (Ammeter, Voltmeter, PF, Energy Consumption with a logger that has communication port of RS 232 shall be provided). Necessary number of MCCB with suitable overload and short circuit rating shall be provided for incomer and outgoing.

3.13 The outgoing of the main SPV panel shall be taken through DC cable with proper protection (Through GI Raceways with suitable size) of suitable rating and shall be hooked up over existing panels/DBs. The rate for any modification of existing panel shall be inclusive of the rate quoted.

3.14 The Contractor shall also furnish 2 sets of the approved manuals of instructions at the time of inspection and taking over of the equipment. These manuals shall be properly bound in book form and contain all information, description of equipment, diagram etc., necessary to enable the customer to operate and maintain the whole system. In order to maintain the plant, Spare parts for keeping minimum stock with measuring instruments are to be provided by the contractor.

3.15 Pre dispatch Inspection of Material

Pre dispatch Inspection of PV Module , Module mounting structure, Inverter, Battery, cables shall be carried out at manufacturer's works/plant by BSF representative. Contractor shall be responsible for arranging the inspection. Any test carried out at plant, the expenditure for the same shall be borne by the contractor. No extra cost shall be paid to contractor for the same.

Inspection call to be given at least 7-10 days in advance.

4.0 CODES AND STANDARDS

All Equipment and accessories shall comply to requirement of standards published by latest MNRE Specifications/ Bureau of Indian Standards (BIS). In case no BIS codes exist the equipments shall meet the requirement of international

standard including IEC/ IEEE for design and installation of PV system. The list of standards adopted shall be indicated in the bid. Latest CPWD specifications to be followed for Electrical works.

In addition to the above standards, the whole system must conform to the relevant National/ International electrical safety standards.

5.0 TOOLS AND SPARES

After completion of installation & commissioning of the power plant, necessary tools & spares are to be provided free of cost by the contractor for maintenance purpose. A list of requisite spares, Fuses, MCCBs etc along with spare set of PV modules to be indicated, shall be supplied along with the equipment.

6.0 ACCEPTANCE OF SYSTEMS AND PERFORMANCE EVALUATION

The installer must verify that the system has been installed according to the manufacturer's procedures and latest MNRE guidelines. A checkout procedure should be developed to ensure an efficient and complete installation.

7.0 SYSTEM DOCUMENTATION:

It is essential that the owner have complete documentation on the system. System documentation should include an owner's manual, warranty certificates, test certificates, as build drawings and copies of relevant drawings for whatever system maintenance might be required in the future.

8.0 INSTALLATION

Installations shall be done by the Qualified engineer who has adequate experience with installation of the PV system.

9.0 TIME SCHEDULE

S.No.	Deliverables	Timelines
1.	Final Architectural and Design Report (soft and 2 Hard copies)	10 days from the date of Signing of Agreement
2.	Draft Final Detailed Project Report(DPR) includes detailed drawings for constructions as per NIT (soft and 2 Hardcopies)	21 days from the date of Signing of Agreement
3.	Final Detailed Project Report(DPR) includes detailed drawings for constructions as per NIT(soft and 3 Hard copies)	9 days from the date of comments on Draft DPR
4.	Supply of material at site	60 Days from the date of Signing of Agreement
5.	Installation, testing and commissioning and handing over of the project	90 days from the date of Signing of Agreement
6.	Onsite comprehensive maintenance and warranty	5 years after and handing over of the project

TECHNICAL SPECIFICATION OF 25 KWP SOLAR POWER PLANT

SI No.	Description	Technical specification
1	Solar Photovoltaic Module (Mono crystalline /Polycrystalline) As per IEC-61215, IEC-61730-1 & 2, IEC-61701, UL listed	350 watt, 72 Nos Size 1965mmx990mmx42mm Efficiency min 19 % / as per manufacturer specification
2	Solar Module mounting structure	Hot dipped Galvanized, fabricated from drawn steel
3	Solar foundation pillars	As per site requirement (RCC based) to be approved by Engg in charge
4	Battery	240 volt, 750 AH Tubular Gel ,Maintenance free type 120 cells of capacity 2 volt, 750 AH each/as per manufacturer specification
5	Power Conditioning Unit (PCU) AS per IEC-60068,IEC-62116, IEC-62040, IEC-61683:1999	25 KVA, 3 phase, 415 volt Efficiency more than 88.00 % Harmonics less than 5% at rated power MPPT voltage 165-265 volt DC (Maximum power point tracker) Nominal grid input voltage 415 volt Battery voltage -240 V Max Input current -70 Amp IP rating IP-20 Frequency 47.5-52.5 Hz
6	Control room building-	120 sq feet (minimum) RCC framed structure MS door 01, MS window 02 Celling fan 02, LED tube fitting 02 Exhaust fan 02, Chemical earthing set 05 set Fire extinguisher and bucket with stand 01 set Lightning arrester set 02 nos)
7	Power cables and electrical accessories	As per manufacturer specification
8	AC Distribution box (ACDB)	All component ISI mark/ As per manufacturer specification
9	DC Distribution box (DCDB)	All component ISI mark/ As per manufacturer specification
10	Array Junction box (FJB)	All component ISI mark/ As per manufacturer specification

CONSTRUCTION OF BATTERY ROOM AT BOPs UNDER SHQ BSF JALPAIGURI.

SLNo	Description	Qty	Unit
1	EARTH WORK		
1.1	Earth work in excavation by mechanical means (Hydraulic excavator) / manual means in foundation trenches or drains (not exceeding 1.5 m in width or 10 sqm on plan), including dressing of sides and ramming of bottoms, lift upto 1.5 m, including getting out the excavated soil and disposal of surplus excavated soil as directed, within a lead of 50 m.		
1.1.1	All kinds of soil.	18.32	cum
1.2	Filling available excavated earth (excluding rock) in trenches, plinth, sides of foundations etc. in layers not exceeding 20cm in depth, consolidating each deposited layer by ramming and watering, lead up to 50 m and lift upto 1.5 m.	21.65	cum
	Sub-Total		
2	CEMENT CONCRETE (CAST IN SITU)		
2.1	Providing and laying in position cement concrete of specified grade excluding the cost of centering and shuttering - All work up to plinth level :		
2.1.1	1:5:10 (1 cement : 5 coarse sand (zone-III) derived from natural sources : 10 graded stone aggregate 40 mm nominal size derived from natural sources)	3.65	cum
2.2	Providing and laying damp-proof course 40mm thick with cement concrete 1:2:4 (1 cement : 2 coarse sand (zone-III) derived from natural sources : 4 graded stone aggregate 12.5mm nominal size derived from natural sources)	3.11	Sqm
2.3	Making plinth protection 50mm thick of cement concrete 1:3:6 (1 cement : 3 coarse sand (zone - III) : 6 graded stone aggregate 20 mm nominal size) over 75mm thick bed of dry brick ballast 40 mm nominal size, well rammed and consolidated and grouted with fine sand, including necessary excavation, leveling & dressing & finishing the top smooth	17.42	Sqm
	Sub-Total		
3	REINFORCED CEMENT CONCRETE		
3.1	Providing and laying in position specified grade of reinforced cement concrete, excluding the cost of centering, shuttering, finishing and reinforcement - All work up to plinth level :		
3.1.1	1:1.5:3 (1 cement : 1.5 coarse sand (zone-III) derived from natural sources : 3 graded stone aggregate 20 mm nominal size derived from natural sources)	7.52	cum
3.2	Reinforced cement concrete work in walls (any thickness), including attached pilasters, buttresses, plinth and string courses, fillets, columns, pillars, piers, abutments, posts and struts etc. above plinth level up to floor five level, excluding cost of centering, shuttering, finishing and reinforcement :		
3.2.1	1:1.5:3 (1 cement : 1.5 coarse sand(zone-III) derived from natural sources : 3 graded stone aggregate 20 mm nominal size derived from natural sources)	2.88	cum
3.3	Reinforced cement concrete work in beams, suspended floors, roofs having slope up to 15° landings, balconies, shelves, chajjas, lintels, bands, plain window sills, staircases and spiral stair cases above plinth level up to floor five level, excluding the cost of centering, shuttering, finishing and reinforcement with 1:1.5:3 (1 cement : 1.5 coarse sand(zone-III) derived from natural sources : 3 graded stone aggregate 20 mm nominal size derived from natural sources).	4.00	cum
3.4	Centering and shuttering including strutting, propping etc. and removal of form for		
3.4.1	Foundations, footings, bases of columns, etc. for mass concrete	28.92	sqm
3.4.2	Suspended floors, roofs, landings, balconies and access platform	3.64	sqm
3.4.3	Lintels, beams, plinth beams, girders, bressumers and cantilevers	7.46	sqm
3.4.4	Columns, Pillars, Piers, Abutments, Posts and Struts	19.20	sqm
3.4.5	Weather shade, Chajjas, corbels etc., including edges	1.22	sqm
3.5	Steel reinforcement for R.C.C. work including straightening, cutting, bending, placing in position and binding all complete upto plinth level.		
3.5.1	Thermo-Mechanically Treated bars of grade Fe-500D or more.	601.60	kg

3.6	Steel reinforcement for R.C.C. work including straightening, cutting, bending, placing in position and binding all complete above plinth level.		
3.6.1	Thermo-Mechanically Treated bars of grade Fe-500D or more.	550.40	kg
	Sub-Total		
4	MASONRY WORK		
4.1	Brick work with common burnt clay F.P.S. (non modular) bricks of class designation 7.5 in foundation and plinth in:		
4.1.1	Cement mortar 1:6 (1 cement : 6 coarse sand)	12.09	cum
4.2	Brick work with common burnt clay F.P.S. (non modular) bricks of class designation 7.5 in superstructure above plinth level up to floor V level in all shapes and sizes in :		
4.2.1	Cement mortar 1:6 (1 cement : 6 coarse sand)	6.75	cum
	Sub-Total		
5	WOOD AND P. V. C. WORK		
5.1	Providing and fixing glazed shutters for doors, windows and clerestory windows using 4 mm thick float glass panes, including ISI marked M.S. pressed butt hinges bright finished of required size with necessary screws. Kiln seasoned and chemically treated hillock wood/Local hard wood.30 mm thick.		
		1.08	sqm
5.2	Providing and fixing ISI marked flush door shutters conforming to IS : 2202 (Part I) non-decorative type, core of block board construction with frame of 1st class hard wood and well matched commercial 3 ply veneering with vertical grains or cross bands and face veneers on both faces of shutters:		
5.2.1	30 mm thick including ISI marked Stainless Steel butt hinges with necessary screws	1.89	sqm
5.3	Providing and fixing ISI marked oxidized M.S. sliding door bolts with nuts and screws etc. complete :		
5.3.1	300x16 mm	1.00	each
5.4	Providing and fixing ISI marked oxidized M.S. tower bolt black finish, (Barrel type) with necessary screws etc. complete :		
5.4.1	250x10 mm	2.00	each
5.5	Providing and fixing ISI marked oxidized M.S. handles conforming to IS:4992 with necessary screws etc. complete :		
5.5.1	125 mm	2.00	each
	Sub-Total		
6	STEEL WORK		
6.1	Providing and fixing T-iron frames for doors, windows and ventilators of mild steel Tee-sections, joints mitered and welded, including fixing of necessary butt hinges and screws and applying a priming coat of approved steel primer.		
6.1.1	Fixing with 15x3 mm lugs 10 cm long embedded in cement concrete block 15x10x10 cm of C.C. 1:3:6 (1 Cement : 3 coarse sand : 6 graded stone aggregate 20 mm nominal size).	32.55	kg
	Sub-Total		
7	FLOORING		
7.1	Cement concrete flooring 1:2:4 (1 cement : 2 coarse sand : 4 graded stone aggregate) finished with a floating coat of neat cement, including cement slurry, but excluding the cost of nosing of steps etc. complete.		
7.1.1	40 mm thick with 20 mm nominal size stone aggregate	7.27	sqm
	Sub-Total		
9	FINISHING		
9.1	12 mm cement plaster of mix :		
9.1.1	1:6 (1 cement: 6 fine sand)	64.54	sqm

9.2	15 mm cement plaster on the rough side of single or half brick wall of mix :		
9.2.1	1:6 (1 cement: 6 fine sand)	32.67	sqm
9.3	Distemping with 1st quality acrylic distemper (ready mixed) having VOC content less than 50 gms/litre, of approved manufacturer, of required shade and colour complete, as per manufacturer's specification.		
9.3.1	Two or more coats on new work	32.67	sqm
9.4	Finishing walls with water proofing cement paint of required shade :		
9.4.1	New work (Two or more coats applied @ 3.84 kg/10 sqm)	38.67	sqm
9.5	Painting with synthetic enamel paint of approved brand and manufacture to give an even shade :		
9.5.1	Two or more coats on new work	9.58	sqm
Electrical portion			
S/N	DESCRIPTION OF ITEM	QTY	UNIT
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with piano type switch, phenolic laminated sheet, suitable size M.S. box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc. as required.		
	Group B	10	Point
2	Wiring for circuit/ sub main wiring along with earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.		
	2 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	20	Meter
	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	20	Meter
3	Supplying and fixing two module stepped type electronic fan regulator on the existing switch box including connections etc. as required.	2	Each
4	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)		
	8 way, Double door	1	Each
5	Supplying and fixing 5 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.		
	Single pole	6	Each
	Single pole and neutral	1	Each
6	Supplying and fixing metal box of 150 mm X 75 mm X 60 mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including providing and fixing 3 pin 5/6 A socket outlet and 5/6 A piano type switch, connections, painting etc. as required.	2	Each
7	Supplying and fixing metal box of 180 mm X 100 mm X 60 mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including providing and fixing 6 pin 5/6 A & 15/16 A socket outlet and 15/16 A piano type switch, connections, painting etc. as required.	2	Each
8	Earthing with G.I. earth pipe 4.5 meter long, 40 mm dia including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. with charcoal/coke and salt as required.	1	Each
9	Providing and laying earth connection from earth electrode with 6 SWG dia G.I. Wire in 15 mm dia G.I. pipe From earth electrode including connection with G.I. thimble excavation and re-filling as required.	10	Meter
10	Providing and fixing 6 SWG dia G.I. wire on surface or in recess for loop earthing as required.	5	Meter
11	Providing and fixing of 300 mm sweep exhaust fan heavy duty 900 rpm in the existing opening, including making good the damage, connection, testing, commissioning etc. as required.	2	Each

12	Providing and fixing the louvers/ shutters complete for a exhaust fan of size 300 mm sweep as directed by engg in charge.	2	Each
13	Providing and fixing of 1200 mms sweep BLDC ceiling fan , including wiring the down rods of standard length (upto 30 cm) with 1.5 sq. mm FRLS PVC insulated, copper conductor, single core cable, including providing and fixing phenolic laminated sheet cover on the fan box etc. as required.	2	Each
14	Supply and fixing of 20 watt, LED flood light fitting directly on wall including connection , earthing etc. as required	4	Each
15	Providing and fixing of 20 watt LED tube fitting Indoor decorative PC housing extruded T5 LED Battens - Integrated type. complete with all accessories directly on wall/surface, including connection with 1.5 sq. mm FRLS PVC insulated, copper conductor, single core cable and earthing etc. as required.	2.000	Each

LIST OF APPROVED MAKES OF EQUIPMENT AND MATERIALS

All material should be as per MNRE approved manufacturer list amended up to date

Sl. No.	Item	Make of Materials/Equipment
1	Inverter/Charge Controller	ENERTECH, LUMINOUS, PPS, SMA , Consul Neowatt or other MNRE approved vendor/manufacturer
2	SPV PANEL	CEL, BEL, BHEL, TATA, Vikram, Usha , Waaree or other MNRE approved vendor/manufacturer
3	Distribution board	Legrand, ABB, schneider, Siemens or other reputed make (ISI Marked)
4	MCB, RCCB, dis-connectors	Legrand, ABB, schneider, Siemens or other reputed make (ISI Marked)
5	DC string cable- copper	Apar/Siechemm/Lapp or other reputed make (ISI Marked)
6	DC main cable	KEI/Polycab/Havells cables or other reputed make (ISI Marked)
7	DC surge protection device	ABB/CITEL/ISKRA or other reputed make (ISI Marked)
8	660/1100 volt grade stranded PVC unsheathed wire with copper conductor	Finolex/RR Kabel/Polycab/KEI/Havells or other reputed make (ISI Marked)
9	Modular type switches, Sockets, bell push, etc	Crabtree, Legrand Mosaic, Anchor, MK Blenze, Northwest make (ISI Marked)
10	1.1kV Cu/Al Cable	Havells/ /Polycab/ KEI (ISI Marked)
11	Conduits PVC/MS	BEC/AKG/ Balco or other reputed make (ISI Marked)
12	Battery	EXIDE, NED, HBL/luminous or other MNRE approved vendor
13	Fan & Exhaust fan	Usha/ Havells/ Orient /CG (ISI Marked)
14	LED Light	Philips/CG/Oshram/Wipro/ (ISI Marked)
15	Ordinary Portland Cement Grade 43/53	BIRLA, JK, ACC, ULTRATECH, JAYPEE, AMBUJA, SHREE
16	Reinforcement Steel	TATA , SAIL, RINL, JINDAL, JSW STEEL, SRMB
17	Wall Putty	JK/BIRLA
18	Paint/Polish/Primer/Water Proofing Paint	BERGER, ASIAN, DULUX
19	Powder Coating	AKZONOBEL, ASIAN
20	Epoxy Paint	FIBREX/BASF
21	Floor & Wall Tile (Vitrified & Ceramic)	KAJARIA, ORIENTBELL , SOMANY
22	Construction/Water proofing Chemical, Admixtures	ROFFE, FOSROC, SIKA, ULTRACON

23	FRLS PVC insulated copper conductor single core cable	Havells//Polycab/Finolex/RR Kabel/HPL/KEI
24	Telephone cable co-axial /TV cable/Lan Wire	Finolex/ Legrand /Anchor/ L&T/ Havells/Polycab/HPL
25	MS/PVC conduit& accessories	AKG/BEC/RMCOM/MKI/Precision (ISI Marked)
26	DWC pipe	Duraline/Jain Irrigation/Avadhpolytube/ Gemini/ISI approved
27	Modular switch socket/telephone socket/cable TV socket/data outlay socket/fan regulator/metal boxes/occupancy sensor	Legrand/Hager/Scheinder / Crab-tree(Havells) /L&T/Anchor
28	Industrial type switch and socket	Legrand/Hager/Scheinder / Crab-tree(Havells) /L&T/Anchor
29	GI pipe (Medium Class)	Tata/Jindal(Hissar)/Bansal- /SuryaPraksh/Utkarsh (ISI Marked)
30	Paints	Asian/Berger/Nerolac
31	Terminal blocks and connector	Elmex/ Connect well/FTC
32	Compact air insulated rising mains	Legrand/Schneider/L&T/Siemens/C&S
33	MCB, MCBDB, RCBO's/RCCB, Isolator, Sheet Steel enclosure	Schneider /Legrand/Siemens/Hager/Havells
34	MCCB/Timer	Schneider -CVS/Legrand/L&T/ ABB/Siemens
35	SFU,FSU, HRC fuses, cable management system/DLP trucking	Schneider /Siemens/C&S/HPL/Havells
36	Ammeter/Voltmeter/Multifunction Meter	Scheinder/L&T/ELMESRE/Secure/HPL/AE
37	Selector switch	Kaycee/Vaishno/L&T
38	Changeover switch	HPL/Socomec
39	LED Indicating lamp	Scheinder/L&T/Vaishno/ABB
40	Panel board/feeder pillar	Manufacturer have ISO 9001 certification/CPRI approved/As mentioned in the schedule
41	Energy meter/Intelligent energy meter/Multifunctional	Scheinder/L&T/ ELMESRE/Secure/AE/ABB
42	Ceiling fan/exhaust fan (only energy efficient fans consuming ≥ 50 W and ≥ 200 for 1200 mm and 60 W and CMM ≥ 240 for 1400 mm shall be used)	Crompton/Havells/Usha/Baja/Orient /Almonard /As mentioned in schedule
43	LED Street/Security Lights	Philips/Bajaj/Crompton/Havells/Wipro/HPL
44	LED Post top lantern	Philips/Bajaj/Crompton/Havells/Wipro/HPL
45	LED Batten Type Fitting/LED Tube/LED Ceiling Fitting/LED Mirror Light/LED Bulk head	Philips/Bajaj/Crompton/Havells/Wipro/ As mentioned in schedule
46	Lamps	Philips/Bajaj/Crompton/Wipro/Havells/ As mentioned in schedule
47	Wall Bracket	Crompton/Havells/Philips/Bajaj/Wipro/ As mentioned in schedule
48	Angle holder /batten holder	Anchor/Kinjal /Cona/ Precision/ISI Make
49	Geysers	Racold/Crompton/Bajaj/Havells
50	Foot Valve, Sluice Valve /NRV/Gate valve/Butterfly Valve	Sant/leader/Kalpana/Zoloto/Kirloskar/Crescent
51	Ball, Gate, Globe Valve (Gunmetal/ISI marked)	Kirloskar/Sant/leader/Kalpana/Zoloto/Honeywell/Rapidcool/Castle/Emerald

Correction = Nil, Insertion = Nil, Overwriting = Nil, Deletion = Nil

EE(ELECT)

52	PVC conduit i/c Accessories ISI marked	AKG/BEC/RMCOM/MKI/Precision/Polycab (ISI Marked)
53	Piano type switches/Sockets/TV/Telephone outlet (ISI mark)	Anchor/Kinjal/Cona/SSK// ISI make
54	ACB	Seimens 3 WL/ L&T U-Power Omega/ Scheinder easy pact (MVS) /Legrand/ABB-Tmax
55	Protection Relays	L&T/Siemens/Minilec/PIC
56	Phenolic laminated sheet ISI marked	Hylum/Formika/Fine/Anchor
57	Transformer	Kirloskar/ABB/Crompton/Scheinder
58	CTs/PTs 15 VA Class-I	Kappa/Rishab/AE/L&T/Logistate
59	MCB Protected Socket	Anchor/Havells/C&S/Scheinder/Legrand/Anchor-Penta/HPL
60	Battery	Exide/Amron/Sukam/Okaya
61	Alarm/Hooter 12V, Response Indication, Fire Alarm panel, Dector,MCP	Bosch/Siemens/Essex/Edwards/Vaishno
62	HDPE pipe	Duraline/Sudhakar/Supreme/Ajaplas/Prince/Rex/ISI make
63	Out door type Cable loop box	Hensel/Cape/Sintex
64	Octagonal Pole	Bajaj/Crompton/Volmont/Transrail/Utkarsh
65	UG Cable aluminum XLPE armoured Cable 1100 V grade	Havells/RR Kabel/Polycab/Gloster/HPL
66	Capacitor	Epcos/L&T/ Schendier/Neptune
67	Thimble/ Lugs& Cable glands	Dowells/Jainsons//Action/Wago/Gripwell/Cornet/Polycab
68	Rising Mains	L&T/C&S/Zeta/Tricolite
69	Octagonal Pole	Bajaj/Crompton/Volment/Transrail
70	Water supply pump and fire pump	Kirloskar/Cromton/Colama/KSB/Texmo/Maller& Plant
71	Fire Extinguishers	Minimax/Lifeguard/Fire shield/Cease fire/D-flame
72	Star Delta Starter	L&T/Siemens/BCH/Scheinder
73	MS Pipe C Class	Tata/Jindal-Hissar/ Bansal/Utkarsh (ISI)
74	Lift	Otis/Koe/Johnson Lifts Pvt Ltd/Mitsubishi/Scheinder
75	M S Cable tray	Elcon/ GRENT/ Hutaib/Cable Tech
76	Anti Vibration Mountings	Dunlop/Resistoflex
77	Cable joints and end termination	Rayschem/3M/Klip Seal/Venus/Denson
78	Bus-bar	Standard/Havells/HPL/L&T
79	Solar street light	As per MNRE specification or Surya/Crompton/Phillips/HPL/Usha/Havells

Note:--The decision of the Engg-In-Charge in regard to use of any particular brand out of above mentioned brands shall be final and binding to the contractor.

SELECTION AND QUALIFYING CRITERIA

1.0 Project Site Visit & Site Conditions

It is seen that the BOP's are located mostly in the remote border areas in the border areas under SHQ BSF Jalpaiguri. There is no proper road connectivity to the sites at BOPs Chandani and Sighpara. This location are across the Tista river. The material has to be transported through small goods carrier/Tractor. At some places material shall be unloaded and loaded again to cross the river through boat/security check/Border Fencing. The rates to be quoted should be inclusive of all above factors.

The BOPs which are located in flood prone areas, special care (elevated structure up to 5 feet etc.) needs to be taken, while designing the Solar PV Plant and control room.

Intending Bidder(s) are advised to satisfy themselves before submitting their bids as to the nature of the ground and sub-soil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence. A bidder(s) shall be deemed to have full knowledge of all the sites whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The bidder(s) shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a bid by a bidder(s) implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the Government and local conditions and other factors having a bearing on the execution of the work.

Please note that site locations are at 01 no BOP of 06 Bn and 01 no BOP of 40 Bn BSF.

FORM "D"
FORMAT FOR UNDERSTANDING THE PROJECT SITE
(on Bidder Letter Head)

To
EXECUTIVE ENGINEER (ELECT)
FTR HQ NB

Subject: Undertaking of the Site Visit for --- (Name of the work / project)

Sir,

I/we hereby certify that I/we have examined & inspected the sites & its surrounding satisfactorily, where the project is to be executed as per the scope of works and quoting my rates accordingly. I/ We are well aware about the following

- a) Location of all proposed site and its allied works.
- b) Site clearance and no cutting off the matured trees.
- c) Topography and contouring of the land where the project is to be executed to understand the cutting & filling during the construction and about depth of column/ foundation below the plinth beam.
- d) Nature of the ground & sub-soil of the site and accessibility to the site.
- e) Existing surrounding road level to finalize solar plant location as per standard norms.
- f) Location of Existing Sewer line & Water pipe line network to connect the proposed building and allied works to make the building functional.
- g) Location of existing buildings, Electric Sub-Station/D.G and proposed solar plant to supply the electricity for the existing buildings and allied works to make the building functional.
- h) Law and order condition at site.
- i) Rules and regulations of Security Agencies/ BSF authorities at BOPs for executing works by external agencies.
- j) Availability of water and construction Material.

Yours faithfully, Date:

(Signature, name and designation
of the Authorized signatory)
Name and seal of Bidder

FORMAT FOR NO DEVIATION CERTIFICATE
 [To be submitted on Bidder's Letter Head+]

To,

EXECUTIVE ENGINEER (ELECT)
FTR HQ NB

Subject: No Deviation Certificate for -----(name of Work /Project)

Dear Sir,

With reference to above this is to confirm that as per Tender conditions we have visited site before submission of our Offer and noted the job content and site condition etc. We also confirm that we have not changed/modified the above tender document and in case of observance of the same at any stage it shall be treated as null and void.

We hereby also confirm that we have not taken any deviation from Tender Clause together with other reference as enumerated in the above referred Notice Inviting Tender and we hereby convey our unconditional acceptance to all terms & conditions as stipulated in the Tender Document.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null and void.

Thanking you,

Yours faithfully, Date:

(Signature, name and designation
of the Authorized signatory)

Place:

Name and seal of Bidder

FORMAT FOR INTEGRITY PACT*To be submitted on Bidder's **Original** Letter Head]

To,
EXECUTIVE ENGINEER (ELECT)
FTR HQ NB

Sub: Integrity Pact for ----- (Name of Work / Project)

Dear Sir,

I/We acknowledge that BSF is committed to follow the principles thereof as enumerated in the Integrity Agreement enclosed with the tender/bid document at **Enclosure-I**.

2. I/We agree that the Notice Inviting Tender (NIT) is an invitation to offer made on the condition that I/We will sign the enclosed integrity Agreement, which is an integral part of tender documents, failing which I/We will stand disqualified from the tendering process. I/We acknowledge that **THE MAKING OF THE BID SHALL BE REGARDED AS AN UNCONDITIONAL AND ABSOLUTE ACCEPTANCE** of this condition of the NIT.

3. I/We confirm acceptance and compliance with the Integrity Agreement in letter and spirit and further agree that execution of the said Integrity Agreement shall be separate and distinct from the main contract, which will come into existence when tender/bid is finally accepted by BSF. I/We acknowledge and accept the duration of the Integrity Agreement, which shall be in the line with Article 1 of the enclosed Integrity Agreement.

4. I/We acknowledge that in the event of my/our failure to sign and accept the Integrity Agreement, while submitting the tender/bid, BSF shall have unqualified, absolute and unfettered right to disqualify the tenderer/bidder and reject the tender/bid in accordance with terms and conditions of the tender/bid.

Yours faithfully,

Date:

Place:

(Signature, name and designation
of the Authorized signatory)

2.0 ADDITIONAL CONDITIONS

1. All deputed Staff/ Manpower/Engineers at different BOPs of BSF should possess valid Police verification document, valid IDs/Aadhar Card as per requirement of BSF.
2. Due to sensitivity of sites and security reasons of BOPs, work shall be executed in day time only (till 5 PM). Manpower shall not be allowed to stay at BOPs .Labour huts / staff residence shall be arranged by contractor at his cost.
3. The contractor shall himself arrange the required Water facility, electricity for construction/ personal purposes at BOPs at his cost.
4. Load/light wiring, fixing/replacement of switches/ sockets, distribution board with MCB etc. of existing buildings at BOP's shall be in Contractor's Scope. Nothing extra shall be paid to contractor for the same.
5. Suitable change-over switches shall be provided for Grid supply/ DG set/ Solar Power at BOPs.
6. The Standard comprehensive Onsite Maintenance and Warranty will be valid for five years including Battery bank from the date of taking over of installation of Solar Plant including repair and replacement of defective parts including batteries. Warranty will be free of cost and nothing will be paid for repair/maintenance or any other job on account of works required to execute during Maintenance and Warranty period.
7. Contractor shall appoint state wise maintenance team and attend any defects within 24 hours
8. Contractor shall sign Service Level Agreement (SLA) with BSF on Rs. 100/- stamp paper as per the standard format approved by BSF.
9. Insurance of all the equipment's installed at site shall be in the Contractor's Scope.
10. Phone, photography, camera not allowed at BOPs.
11. The Contractor shall be responsible for consequential effects arising out during the inspection done by the Chief Technical Examiner Cell, Central Vigilance Commission or by the Building Works Committee or third party authorized by BSF or any statutory committee or by any duly authorized representative of BSF, during the progress or any time after the construction and development of project up to the defect liability period, and will take appropriate action for rectification of defective work. Rectification of defective works or replacement of sub-standard materials or articles, as pointed out by the Chief Technical Cell, Central Vigilance Commission, Building Works Committee or authorized representative of BSF or third party authorized by BSF or any statutory committee, will be carried out or replaced by the Contractor at his own risk and cost. BSF will not pay any extra amount for such rectification or replacement.
12. Handing Over of the Project: Contractor will hand over the project to Owner /Client after successful completion of each component of the project in all respect and complete satisfaction of Engineer-In-charge. The partial handing over of project components shall not be considered. Contractor shall also provide necessary Completion Certificate. The onsite maintenance and warranty period will be five years after such handing over.

Correction = Nil, Insertion = Nil, Overwriting = Nil, Deletion = Nil

EE(ELECT)

13. The Contractor shall render all help and assistance in documenting the total sequence of this project by way of photography, slides, audio-video recording etc. nothing extra shall be payable to the agency on this account.

14. Contractor shall arrange water electricity food and lodging at his own cost for workers employed at site, his technical staff and site staff.

15. The work will be commenced by the Contractor only after the approval of drawings from the concerned local authorities including fire fighting's department or any other department as per statutory requirement.

16. The Contractor shall be solely responsible to follow the general clauses of the contract including labour regulations, registration of contractor, obtaining labour license from labour department, safety precautions, etc. and all other statutory provisions related to labor/works as per the prevailing General Clauses of Contract amended from time to time. The Contractor shall stick to the schedule of all activities and carry out it with mutually agreed time frame.

17. Rates and amount Quoted by contractor shall be firm and fixed for entire contract period as well as extended period for completion of the works. No escalation shall be applicable on this contract.

18. Unless otherwise provided in the schedule of quantities the rates tendered by the contractor shall be all inclusive and shall apply to all heights lifts, leads and depths of the structure and nothing extra shall be payable on this account.

19. The contractor shall make his own arrangements for obtaining electric connection and water Connection/arrangement (if required) and make necessary payments directly to the department concerned. No dispute in this regard shall be entertained.

20. Some restrictions may be imposed by the security staff etc. on the working and for movement for labour materials etc. The contractor shall be bound to follow all such restrictions / instructions and nothing extra shall be payable on this account. Labours are not allowed to stay at site after 5 P.M.

21. (a) The Project work will be carried out in the manner complying in all respects with the requirements of relevant bye laws of the local body under the jurisdiction of which the work is to be executed or as directed by the Engineer in charge and nothing extra will be paid on this account.

(b) The contractor shall comply with proper and legal orders and directions of the local or public authority or municipality and abide by their rule and regulations and pay all fees and charges which he may be liable.

22. The contractor shall give a performance test of the entire installation (s) as per standing specification before the work is finally accepted and nothing extra whatsoever shall be payable to the contractor for the test.

23. The work shall be carried out in accordance with the drawings approved, by the Engineer-in-Charge.

24. The contractor shall bear all incidental charges for cartage, storage and safe custody of materials.

Correction = Nil, Insertion = Nil, Overwriting = Nil, Deletion = Nil

EE(ELECT)

25. The contractor shall have to make approaches to the site, if so required and keep them in good condition for transportation of labour and materials as well as inspection of works by the Engineer in charge. Nothing extra shall be paid on this account.

26. No payment will be made to the contractor for damage caused by any accidents, rains, or other natural calamities during the execution of the works and no such claim on this account will be entertained.

27. Various factory made materials shall be procured from reputed and MNRE approved manufacturers or their authorized dealers. List of such approved manufacturers is available at Annexure VII. For the items / materials not appearing in the list the decision of Engineer in charge shall be final and binding.

28. The contractor shall take instruction from the Engineer in charge for stacking of materials at any place..

29. The material shall conform to the quality and make as per attached list in Annexure VII. However for the items not appearing in the list preference shall be given to those articles which bear ISI certification marks. In case articles bearing ISI certification marks are not available the quality of sample brought by the Contractor shall be judged by the standard laid down in the relevant ISI specification/CPWD/MNRE specification. All materials and articles brought by the contractor to the site for use shall conform to the samples approved, which shall be preserved till the completion of the work. However, such articles which bear ISI mark but stand banned by CPWD/MNRE will not be used. Notwithstanding the case of materials of "Preferred Make" as given in Annexure VII, provisions of Clause 10A of the General Conditions of Contract for Central PWD works shall be applicable on the materials of "Preferred Make" also.

30. It must be ensure that all materials to be used in work bear BIS certification mark. In cases where BIS certification system is available for a particular material/product but not even a single producer has so far approached BIS for certification the material can be used subject to the condition that it should confirm to CPWD specification/MNRE

31. Specifications and relevant BIS codes. In such case written approval of the Engineer-In-Charge may be obtained before use of such material in the work.

32. The final approval of the brand to be used shall be as per the direction of Engineer-in-Charge. The brand used shall be one of the brands in case specified in the list of preferred make / materials annexure-VII.

33. In case of non-availability of material of the brands specified in the list of approved materials an equivalent brand may be used after getting written approval of BSF giving details to indicate that the brand proposed to be used is equivalent to the brands mentioned in the agreement.

34. Removal of rejected/sub-standard materials.

The following procedure shall be followed for the removal of rejected/sub-standard materials from the site of work:

(i) Whenever any material brought by the contractor to the site of work is rejected, entry thereof should invariably be made in the Site Order Book under the signature of the Engineer-In-Charge, giving the approximate quantity of such materials.

(ii) As soon as the material is removed, a certificate to that effect shall be recorded by the Engineer-In-Charge against the original entry, giving, the date of removal and mode of removal, i.e., whether by

Correction = Nil, Insertion = Nil, Overwriting = Nil, Deletion = Nil

EE(ELECT)

truck, carts, or by manual labour. If the removal is by truck, the registration number of the truck should be recorded.

(iii) When it is not possible for the Engineer-In-Charge to be present at the site of work at the time of actual removal of the rejected/sub-standard materials from the site, the required certificate should be recorded by the Authorized Representative of BSF, and the Engineer-In-Charge should countersign the certificate recorded by the Authorized Representative.

35. The contractor has to take permission from the BSF & local authorities etc. if required for work during night hours. No claim / hindrance on this account shall be considered if work is not allowed during night time.

36. Once the Project is completed and the contractor shall be responsible to attend defect pointed out by BSF and then hand over the Project to the client.

37. Contractor must provide following documents after completion of work.

- a. Site photos of 25 KWP solar power plant of concern BOPs.
- b. Single line diagram of 25 KWP solar power plant.
- c. Warranty certificate of 25 KWP solar power plant.
- d. Site completion and fitness certificate.
- e. Project handing over report.

For & on behalf of Tenderer

SCHEDULE OF QTY

Name of Work: Supplying, installation, testing and commissioning of 25 KWp off Grid Solar Power Plant at BOP Chandani of 06 Bn and BOP Singhpara of 40 Bn BSF, under SHQ BSF Jalpaiguri

S No	Particular	QTY	UNIT	RATE	AMOUNT
1	<p>Supply, Installation, Testing and Commissioning of Hybrid/off-grid (with the provision to charge from main power source) Solar Photovoltaic Power Plant conforming to MNRE specifications as amended, consisting of Mono/Poly Crystalline silicon solar cells, necessary protections, earthing, mounted on RCC structure of suitable strength with following components complete as required as per Appdx "A" The rates quoted should be inclusive of all taxes, transportation charges , loading/unloading at site etc as reqd:-</p> <p>a) Solar Photovoltaic Module of capacity 350 Wp or above, manufactured in India, conforming to IS 14286/IEC 61215, IS/IEC 61730-Part-1, IS/IEC 61730-Part-2. Solar Photovoltaic Module conversion efficiency shall not be less than 16.5%. PV modules used in solar power plants/ systems must be warranted for their output peak watt capacity, which should not be less than 90% at the end of 10 years and 80% at the end of 25 years.</p> <p>b) Power Conditioning Unit (PCU) of 350-800 V DC Input voltage range and 400 V AC, three phase, 4 wire, 50Hz +/- 2.5 Hz, output voltage suitable to generate AC Power with efficiency not less than 97%, total harmonic distortion less than 3% and suitable for ambient temperature from 0 to 50 degree C.</p> <p>c) Data Monitoring System complete with accessories.</p> <p>d) Fixing of Array junction box & Main junction box with IP 65 protection and termination arrangement for incoming and outgoing cable along with glands, lugs and other accessories etc. as required.</p> <p>e) Lightning and surge voltage protection.</p> <p>f) Connections & Interconnections by supplying & fixing required size XLPE insulated copper conductor 1.1 kV grade armoured power and control cables between solar modules, main power cable to grid supply PCU unit along with supplying & fixing of necessary channel/conduit lugs and other accessories etc. as required.</p> <p>g) Battery bank of required capacity of solar plant</p>	02	Set		
2	<p>Cost for construction of RCC structure for Battery bank / Control room shall be of size 120 sq. feet (minimum), with head room of minimum 2.9 meters & plinth height shall be minimum 1.8 meter (minimum) from natural ground level as per drawing to be approved by Engineer-in-charge. The flooring should be of RCC (must withstand the load of batteries and other equipment). Steel gate, window-02 nos (minimum) , opening for exhaust must be installed in control room. Roof of control room must be so designed to prevent water lodging etc. complete as per Scope of Work & Technical Specifications mentioned in Appendix- B</p>	02	JOB		

Correction = Nil, Insertion = Nil, Overwriting = Nil, Deletion = Nil

EE(ELECT)

3	Supplying and fixing of 15 watt All in one Solar Street Light is made with High Efficiency Mono Crystalline Solar PV Module, Lithium Ferro Phosphate battery with in-built BMS technology, High Efficacy LED, MPPT Solar Charge Controller and Aluminium Extruded body & is specially programmed to automatically control the dimming and rightness of light, which increases the backup time and alluminume outdoor solar powered surveillance system with street light illumination (CCTV system) with pole mounted complete set including 6 mtr pole and base foundation etc as req. As per MNRE specification or Surya/Crompton/Phillips/HPL/Usha/Havells	06	Each		
Total Rs.					

Dy Comdt/EE (Elect)
FTR HQ BSF NB